

CORRECT (low frequency):
loop is open, no current can circulate



✕
shield floats
(no connection)

▲
shield grounded
(one end)

INCORRECT (low frequency):
both-ends ground closes the loop



▲
shield grounded

▲
shield grounded
(both ends!)

↪
circulating current from ground
potential difference between the two ends