



MODULA
A JSW Enterprise

Site Validation Checksheet

Date:

Client Name:

TO DO LIST

***All the points mentioned below must be executed & after execution check box must be ticked in & if not done then cross mark the check box.**

Check
Box

Masking of LC as per final design with cabinet name written in it

☐

Remarks

Masking of UC as per final design with cabinet name written in it

☐

Masking of TT as per final design with cabinet name written in it

☐

Masking of Loft as per final design with cabinet name written in it

☐

Masking of Island as per final design with cabinet name written in it

☐

Kitchen Wall surface level to be checked with 600mm spirit level at 5 to 6 places for one wall

☐

Validate

***All the Points mentioned must be validated & if it is correct tick mark the check box & if it is not okay cross mark the check box & write remarks in the coloumn given.**

After masking all cabinet fits in the given space

☐

Remarks

Minimum 50mm filler at all space between cabinets and adjacent wall & 100mm between loft & ceiling.

☐

Minimum 920mm distance between parallel Cabinets

☐

False ceiling drop (if not constructed) must be 100mm above loft cabinet

☐

Gas pipeline inlet point as per MEP/EPT & Standard defined

☐

Electrical points as per MEP/EPT & Standard defined (Ref. Table SVC02)

☐

Gas Pipeline flow must not come behind any cabinet

☐

Plumbing points as per MEP/EPT & Standard defined (Ref. Table SVC03)

☐

Hood/Chimney Unit must have 10mm or more width then chimney width

☐

Chimney width as per Specification, actual space left at site

☐

Kitchen Wall surface in level

☐

All visible ends of kitchen have end panels in drawing

☐

Lower Cabinet corner unit must be considered 80mm more in width for 630 depth cabinet & 40mm more in width for 590 depth cabinet during masking (Dead space calculation formula, X+ Cabinet width= Depth of perpendicular cabinet+ 50mm+ Shutter size of corner unit).

☐

Dead Space left between corner unit & wall parallel to it

☐

Corner unit wall must be of 90 degree.

☐

Upper Cabinet corner unit must not be less than 800mm

☐

For single door fridge 100mm more width space should be left out & for double door fridge 200mm more width space should be left out

☐

Fridge width, height as per specification. Actual width left, height for fridge.

☐

Wherever there is UP & Over cabinet there must not be any loft above it(Check appliance unit & UC with UP & over hardware & if there is loft above it.)

☐

End Panel must always be there at each end of frame loft whether it is visible end or not.

☐

Topline Wardrobe must not have loft above it

☐

50mm fillers above wardrobe loft & between walls & Wardrobe

☐

Remarks

Site Validation Checksheet

ETP/MEP Standards

Table SVC01 Electrical equipment & power needed for it	
Appliance	Power
Hob	15 Amp
Chimney	15 Amp
Oven(In Built)	15 Amp
Microwave(In Built)	15 Amp
Light Point	5 Amp
Fridge	15 Amp
Dishwasher	15 Amp
Under Sink RO	5 Amp
Wall RO	15 Amp
Geyser	15 Amp
Wall Microwave	15 Amp
Washing Machine	15 Amp
Switch Board	as per requirement

Table SVC02 Distance of electrical Points from Vertical panel & FFL		
Appliance	Height from FFL	Distance from vertical panel of cabinet
Hob	700mm	200mm
Chimney	2000mm	In centre of Hood unit
Oven(In Built)	800mm	100mm
Microwave(In Built)	1350mm	100mm
Light Point	50mm above UC	50mm from side wall
Fridge	1100mm	200mm
Dishwasher	500mm(in sink unit)	100mm(in sink unit)
Under Sink RO	500mm	100mm
Wall RO	2000mm	100mm
Geyser	as per requirement	200mm from wall
Wall Microwave	1650mm	100mm
Washing Machine	500mm	100mm
Switch Board	1100mm	As per requirement

Table SVC03 Distance of Plumbing Points from Vertical panel & FFL		
Appliance	Height from FFL	Distance from vertical panel of cabinet
Under Sink RO(cold water)	450mm	80mm Centre of cabinet
Under Sink (Hot water)	450mm	Centre of cabinet
Under Sink (Cold water)	450mm	80mm Centre of cabinet
Waste water on wall	350mm	Centre of cabinet
Wall RO(Inlet)	1630mm	100mm from vertical panel of cabinet.
Wall RO(Outlet)	1630mm	150mm from vertical panel of cabinet.
Dishwasher(Inlet)	450mm(In sink unit)	100mm from vertical of sink unit.
Dishwasher(Outlet)	350mm (In sink unit)	150mm from vertical panel of sink unit.
Wall Sink (Cold)	1100mm	Centre of cabinet
Wall Sink (Hot)	1100mm	50mm from centre of cabinet
Washing Machine(Inlet)	450mm	Centre of cabinet
Washing Machine(Outlet)	350mm	50mm from centre of cabinet
Geyser(Inlet)	as per requirement	as per requirement
Geyser(Outlet)	as per requirement	as per requirement

#All the above dimension can vary up to max 80mm from the given standard, although non of the above points can come behind of any of the panel of carcass of cabinet.

- Note:**
- Shutter opening need to be checked.
 - If filler is not there shutter will hit the wall.
 - If shutter opening is chimney/fridge side then shutter will bang on appliance.
 - Working & walking space needs to be checked.(Between two parallel counter minimum 3ft space needed, kitchen triangle must be followed, that is perimeter of triangle with sink,hob & fridge at three corner should be minimum 12ft & maximum 26ft.)
 - Island marking, If Island chimney it's hanging point need to checked, hob gas pipeline need to checked for island.
 - If under Counter Chimney is there check its specification and do marking as per specification.(check its motor placement point, exhaust outlet point)

Accessories & document needed for site validation:

- Final Drawing.
- Site Measurements report.
- MEP/EPT Drawing.
- Laser level tool.
- Masking tape, Marker/Chalk.
- Measuring tape.
- Specification(length,width,height & power needed) of all the appliances in the kitchen(Hob, Chimney, Oven, Microwave,Dishwasher & fridge).
- Spirit level of 600mm.