

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE,

NO. PHC/Sarbhon/2

Date:- 12/5/26.

It is certified that an inspection team headed by medical officer (Name of
Officers the with designation) from Primary health center (PHC) (Name of
Sarbhon
Department/Office) inspected the Shree Radhugovind vidyamanidar, Nimat
_____ (Name & Address of the School) on _____ and
found that the Shree Radhugovind vidyamanidar (Name
of school) has safe drinking water facilities for the students and members of staff of the institution and
is maintaining the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/UT Govt.

The above valid for a period of 1 year

Signature with Seal:

Name :

Designation :


MEDICAL OFFICER
P. H. C. SARBHON
TAL. BARDOLI, DIST. SURAT
Dr. Mitesh D. Patel
M. O - P. H. C - Sarbhon,
Ta - Bardoli, Dist - Surat

To

Shree Radhugovind vidyamanidar,
Nimat, Ta - Bardoli,
Dist - Surat - 394350

(Name & Address of the Institution)

TO :

August 19, 2026

**Shree Radhagovind Vidyamandir,
Ninat.**

Subject: Regarding drinking water Parameter in school and Hostel

Respected Sir,

As per subject we have instaled and doing service of RO plant in school and Hostel of Shree Radhagovind Vidyamandir on regular basis. The drinking water quality is hygienic and Parameter are given below.

- (1) Raw water TDS: 550 PPM**
- (2) Finished water TDS: 66 PPM**
- (3) Finished water PH: 7.6**

Regards,

NEERVANA ENTERPRISE

S.D.
PROPRIETOR !

Siddharth Acharya