


## **BUILDING SAFETY CERTIFICATE**


The building of **Sun Rise Model Public School Kandi Dholran,**


Tehsil Baroh in Distt. Kangra (HP) was inspected by the concerned Junior Engineer on dated 18-02-2021 and as per the report of Junior Engineer this building has neither been designed nor been constructed by this office. No earth quake resistant norms have been adopted for this building. No structural drawings approved by the competent Govt. agency have been produced. The structure is a non-Engineered structure, hence the structure safety of this building cannot be ensured specifically from the earth quake point of view. This department will not responsible for any type of loss of property etc., if this structure fails under any circumstance. However as per visual inspection the building has been found to be safe at present only. This is valid for one year i.e 31.03.2022. Fee amounting to Rs. 1500/- only has been deposited Vide E Challan No.A21B178170 Dated 18.02.2021

Place:- Baroh

Dated:-18-02-2021

  
Junior Engineer,  
Baroh Sub-Division,  
HP. PWD Baroh.

  
Assistant Engineer,  
Baroh Sub Division,  
HP PWD Baroh.

  
Executive Engineer,  
HP PWD Division,  
Tanda at Nagrota Bagwan