CENTRALA SONORIZARE
LEGENDA
LEGEND
CENTRALA SONORIZARE
Centrala sonorizare 500 W.6 zone ,cu iesire dubla pe fiecare zona ,display 4.3",consola pompier inclusa si amplificator de rezerva, 100 Vca/24Vcc cu acumulatori 2x18 Ah inclusi,certificata EN-54
Sound system 500 W central panel, 6 zones, with double output on each zone, 4.3 "display, fire console included and spare amplifier, 100 VAC / 24Vdc with 2x18 Ah batteries included, EN-54 certified
CENTRALA SONORIZARE
Centrala sonorizare 500 W.4 zone ,cu iesire dubla pe fiecare zona ,display 4.3",consola pompier inclusa si amplificator de rezerva, 100 Vca/24Vcc cu acumulatori 2x18 Ah inclusi,certificata EN-54
Sound system 500 W central panel, 4 zones, with double output on each zone, 4.3 "display, fire console included and spare amplifier, 100 VAC / 24Vdc with 2x18 Ah batteries included, EN-54 certified
DIFUZOR DE PLAFON
1,5/3/6 W conectat la treapta de putere 3W
CEILING SPEAKER
1,5 / 3/6 W connected to 3W power stage
DIFUZOR PROIECTOR, de exterior, 1,25/2,5/5/10 W conectat la treapta de putere 5W
PROJECTOR SPEAKER, outdoor, 1,25 / 2,5 / 5/10 W connected to 5W power stage
CONSOLA DIGITALA MONITORIZATA CU MICROFON
DIGITAL MONITORED CONSOLE WITH MICROPHONE
CONSOLA POMPIERI DIGITALA MONITORIZATA CU MICROFON
DIGITAL FIRE CONSOLE MONITORED WITH MICROPHONE
CABLU REZISTENT LA FOC E90/FE180 2X1,5 mm
FIRE RESISTANT CABLE E90 / FE180 2X1,5 mm
CABLU JE-H(St)H 4x2x0.8mm²
JE-H (St) H CABLE 4x2x0.8mm²
CABLU CAT5 SFTP
CAT5 SFTP CABLE
DIFx/y/z
Numar difuzor
Speaker number
Numar centrala sonorizare
Sound system panel number
Numar zona
Zone number
CATEGORIA DE IMPORTANTA - A (cnf. H.G.R.NR.766-1997)
CLASA DE IMPORTANTA - I (cnf. Normativ P100-06)
GRAD DE REZISTENTA LA FOC - I - II (cnf. Normativ P118-1999)
RISC DE INCENDIU - MIC (cnf. Normativ P118-1999)
VERIFICATOR / EXPERT
NUME
SEMNATURA
CERINTELE
REFERAT de verificare/ RAPORT de expertiza tehnica
Nr. -
Data: -
TRACTEBEL
ATELIER DE ARCHITECTURE CHRISTIAN TANASESCAUX
Proiect : Interconectarea cladirilor existente si constructie noua in incinta Spitalului Clinic Judetean de Urgente «Pius Branzeu» - Timisoara, in vederea reorganizarii circuitelor functionale ale Departamentelor UPU, Chirurgie, ATI si Centru de Mari Arsi
Pr. Nr: P.013049
Locatie : Bulevardul Liviu Rebreanu 156, Timisoara 300723
Beneficiar Investitor : Consiliul Judetean Timis
: Ministerul Sanatatii - Romania
SPECIFICATIE
NUME
SEMNATURA
Scara: 1:100
Format: A0+
Data: FEBRUARIE 2021
Denumire desen:
PLAN SONORIZARE SUBSOL
Basement sound system plan
Fazat: PT+DE
Rev. 01
Pagina 1/1
Nr desen: P.013049_D8_IEC5040