




Parter Groundfloor




Etaj2 2nd Floor




Etaj44th Floor

















Etaj1 1st Floor






Etaj3 3rd Floor



LEGENDA **LEGEND**

	IZOLATOR SURSE BUS/SCS BUS/SCS sources isolator
	SURSA ALIMENTARE 230 Vca/24Vd, 1.2A Power supply 230vac/24Vdc, 1.2A
	SURSA ALIMENTARE BUS/SCS 230 Vca /24 Vdc, 1.2A BUS / SCS POWER SUPPLY 230vac/24Vdc, 1.2A
	UNITATE SALON-CU DISPLAY Room door unit with display
	EXPANDER DE LA 2 LA 4 PATURI Expandre from 2 to 4 beds
	UNITATE PRINCIPALA ASISTENTE CU DISPLAY Main control unit with display for nurses
	UNITATE SECUNDARA ASISTENTE CU DISPLAY Secondary control unit with display for nurses
	UNITATE BAIE-CU LED Bathroom door unit with LED
	INDICATOR R+B+V SALON R+B+V room indicator
	SISTEM APELARE ASISTENTA FORMAT DIN TELECOMANDA, PRIZA MAGNETICA SI DOZA 2M, ANTIMICROBIAN Nurse call system consisting of remote control, magnetic socket and 2M box, antimicrobial
	SISTEM APELARE ASISTENTA CU SNUR, PENTRU MONTAJ IN BAI CU PRIZA MAGNETICA SI DOZA 2M, ANTIMICROBIAN Cord nurse call system, for bathrooms monting with magnetic socket and 2M box, antimicrobial
	Cabluri BUS/SCS 1x2x0.35mm2 BUS/SCS 1x2x0.35mm2 cable
	Cabluri alimentare 2x1mm2 2x1mm2 power supply cable
	Cabluri alimentare 4x1mm2 4x1mm2 power supply cable

VERIFICATOR / EXEMPLU		NUME		SEMNAȚURA		CENTINȚELE		REFERAT DE VERIFICARE RAPORT DE EXPERTIZĂ TEHNICĂ Nr. _____		Pr. Nr. P-01049	
 <small>Tractebel Engineering S.A. Societate cu capital 100% românesc Sediu: Strada 13 Noiembrie 1989, Nr. 10 București, România Tel: +40 21 312 20 00 Fax: +40 21 312 20 01 E-mail: info@tractebel.ro</small>		 <small>ING. CRISTIAN TANASCAUX</small>						Proiect: Interconectarea de înaltă tensiune a conductoarelor în aer între Spania/Grecia, Județul de Urgențe / în aer între România / în aer interconectare conductoarele medicale dintre județele: LPU, Cluj-Napoca, ATU și Constanța de Nord-Est Localte Beneficiare: Substanțiuța LPU, Romania - 100, Cluj-Napoca 300723 Comandă Județeană: Municipiul Săvârșin - Romania		Faza: PP-DE	
SPECIFICATE		NUME		SEMNAȚURA		Scara = _____		Data = _____		Rev. 00	
SEF PROIECT		Ing. Cristian TANASCAUX				Format: A4		Descrierea desenului		Schema bloc curent	
VERIFICAT		Ing. IULIA PRASADELESCU				Data = _____		Schema bloc curent Nurse cu bloc nurse		Pag. 1/1	
VERIFICAT		Ing. Aurelia MITA				Data = _____					
DESEINAT		Ing. Florin Tanase				Data = _____					
PROIECTAT		Ing. Florin Tanase				Data = _____					
						Data = _____		Nr. desen: P-01049_DE_ECS650			