

LEGENDA
LEGEND:

- Ceas Master Clock pentru aplicatii medicale cu receptor GPS inclusiv antena
  Master Clock for medical applications with GPS receiver including antenna
- Ceas Master Clock cu receptor GPS inclusiv antena
  Master Clock with GPS receiver including antenna
- Ceas digital medical Slave (ore,minute,secunde ,cromometru+telecomanda) fata simpla ,montaj pe perete sau tavan,unghi citire 120°,distanta citire 0-20 metri
  Slave digital medical clock (hours, minutes, seconds chronometer + remote control) single front, wall or ceiling mounting, reading angle 120 °, reading distance 0-20 meters
- Ceas digital Slave (ore,minute) fata dubla ,montaj pe perete sau tavan,unghi citire 120°,distanta citire 0-40 metri
  Slave digital clock (hours, minutes) double face, wall or ceiling mounting, reading angle 120 °, reading distance 0-40 meters
- Ceas analogic Slave (ore,minute) fata simpla ,montaj pe perete sau tavan,distanta citire 0-20 metri
  Slave analog clock (hours, minutes) single face, wall or ceiling mounting, reading distance 0-20 meters
- Amplificator de impuls
  Impulse amplifier
- Legatura LAN
  LAN connection
- Cablu UTP LSZH 4x0.5 mmp pentru circuit ceas medical
  UTP LSZH 4x0.5 mmp cable for power supply medical clock circuit
- Cablu UTP LSZH 4x0.5 mmp pentru circuit ceas
  UTP LSZH 4x0.5 mmp cable for power supply clock circuit
- Cablu N2XH 3x2.5 mmp pentru circuit alimentare ceasuri digitale
  N2XH 3x2.5 mmp cable for power supply digital clocks

Ceas analogic / Nivel	CA.P 1/2/9	Numar ceas / Numar zona / Master clock	Analog clock / Floor
Ceas digital / Nivel	CD.P 1/3/2	Numar ceas / Numar zona / Master clock	Digital clock / Floor
Ceas digital medical / Nivel	CDM.P 2/4/6	Numar ceas / Numar zona / Master clock	Medical digital clock / Floor

CA.P 1/2/9: Clock's number / Area's number / Master clock
CD.P 1/3/2: Clock's number / Area's number / Master clock
CDM.P 2/4/6: Clock's number / Area's number / Master clock

CATEGORIA DE IMPORTANTA	- A	(cnf. H.G.R.NR.766-1997)
CLASA DE IMPORTANTA	- I	(cnf. Normativ P100-06)
GRAD DE REZISTENTA LA FOC	- I - II	(cnf. Normativ P118-1999)
RISC DE INCENDIU	- MIC	(cnf. Normativ P118-1999)

VERIFICATOR / EXPERT	NUME	SEMNATURA	CERINTELE

TRACTEBEL ENGINEERING S.A.
Str. Antoni Mureșanu nr. 16, Cluj-Napoca, 400609, Romania
Tel: +40 (0) 264 - 431 - 650, Fax: +40 (0) 264 - 431 - 651
E-mail: info@tractebel-engineering.ro
http://www.tractebel-engineering.ro

ATELIER DE ARHITECTURĂ CHRISTIAN TANASCAUX

REFERAT de verificare/ RAPORT de expertiza tehnica
Nr. - Data: -

Proiect : Interconectarea cladirilor existente si constructe noua in incinta Spitalului Clinic Judetean de Urgente + Plus Bratuia + Timisoara. In vederea reorganizarii circuitelor medicale pentru departamentele: UPU, Chirurgie, ATI si Centru de Mari Ars.

Locatie : Bulevardul Liviu Rebreanu 156, Timisoara 300723
Beneficiar : Consiliul Judetean Timis
Investitor : Ministerul Sanatatii - Romania

Denumire desen: **Plan ceasoficare etaj 4**
4TH floor clocks network plan

SPECIFICATIE	NUME	SEMNATURA	Scara: 1:100
SEF PROIECT	Arh.Christian TANASCAUX		Format: A0+
MANAGER PROIECT	Ing. Liviu POPA-BELEGANTE		Data:
VERIFICAT	Ing. Aurelian NETA		FEBRUARIE 2021
DESENAT	Ing. Florin Tanase		
PROIECTAT	Ing. Florin Tanase		

Pr. Nr: P-013049
Faza: PT+DE
Rev. 01
Pagina 1/1
Nr desen: P-013049_D8_IEC5037