

FIELD INSPECTION NOTE

Equipment Tag: V-770

Type: Pressure Relief Valve

Location: North Yard Compressor Station

Inspection Date: 2026-07-10

Next Due Date: 2026-10-10

Inspector: M. Delacroix

Status: OK - set pressure verified

Notes: Popped and reseated cleanly at 150 psig, no leakage after reseal.