

SYNTHETIC DEMONSTRATION DATA -- FOR EVALUATION ONLY

REFINERY STANDARD OPERATING PROCEDURE

Document ID: SOP-MAINT-001 (Version 2.4)

Title: Rotating Equipment Bearing Temperature & Vibration Monitoring

1. Operating Limits:

Normal bearing operating temperature for pumps and motors is up to 80 degrees C.

Maximum continuous operating limit is 80 degrees C.

2. Mandatory Actions:

If bearing temperature exceeds 80 degrees C, record temperature and inspect bearing immediately.

Schedule maintenance inspection within 24 hours to prevent cataclysmic bearing seizure.

SYNTHETIC DEMONSTRATION DATA -- FOR EVALUATION ONLY
SOP-MAINT-001 -- CORRECTIVE ACTIONS & APPROVAL PROCESS

3. Corrective Actions for Thermal Exceedance (> 80 C):

- Isolate secondary bypass if safe to do so.
- Check oil reservoir and replace contaminated lubricant.
- Check axial alignment and mechanical seal condition.

4. Approval Authority:

All repairs on Class-1 rotating equipment require an Approval Note signed by Lead Maintenance Engineer.