

SYNTHETIC DEMONSTRATION DATA -- FOR EVALUATION ONLY

EQUIPMENT INSPECTION REPORT -- PUMP-03

Asset ID: Pump-03 (Crude Distillation Unit Cooling Water Booster)

Inspection Date: 2026-08-15

Observed Bearing Temperature: 92 degrees C under full operating load.

Visual Inspection: Heavy casing vibration detected on bearing housing.

Operating Status: Continuous service; abnormal heating observed during routine daily round.

Reported By: Senior Reliability Engineer (Demo Account)

SYNTHETIC DEMONSTRATION DATA -- FOR EVALUATION ONLY

PUMP-03 HISTORICAL LOGS AND SENSOR READINGS

Vibration Level: 6.8 mm/s RMS (ISO 10816-3 Zone C/D Limit is 4.5 mm/s)

Lubrication Oil Level: Low with slight discoloration.

Maintenance Urgency: High priority inspection recommended.