

INDUSTRIAL INSPECTION GUIDELINES & SEVERITY STANDARDS

Document ID: SOP-INSP-003

Document Type: sop

Revision: Rev 1.4

Effective Date: 2026-02-15

Department: Quality Assurance & Reliability

1. Inspection Regimes and Frequency

Rotating machinery must undergo systematic surveillance:

- Daily routine inspection: Thermal imaging, surface temperature, audible checks.
- Monthly comprehensive inspection: Vibration spectral analysis, oil sampling.
- Quarterly shutdown audit: Internal bearing clearance, seal inspection.

2. Severity Classification Matrix

Observations must be categorized according to deviation from baseline:

- HIGH SEVERITY: Parameter exceeds continuous limit by > 10% (e.g. Temp > 88 C).
Action: Immediate operational restriction and expedited maintenance review.
- MEDIUM SEVERITY: Parameter between normal baseline and limit (75 C - 80 C).
Action: Schedule maintenance inspection within 48 hours.
- LOW SEVERITY: Minor aesthetic or non-functional observation (e.g. minor paint wear).
Action: Log observation and monitor during next scheduled cycle.

INDUSTRIAL INSPECTION GUIDELINES & SEVERITY STANDARDS

Document ID: SOP-INSP-003 (Page 2)

3. Evidence Recording and Traceability

Every recorded inspection finding must capture:

- Asset / equipment identifier (e.g. Pump-03)
- Quantitative observed value with physical unit of measurement (e.g. 92 C)
- Benchmark operating limit from authoritative SOP (e.g. 80 C)
- Exact document source, page number, and paragraph citation.

4. Approval Note Preparation

Approval notes must synthesize findings, technical analysis against SOP thresholds, risk rating, recommended remedial actions, and authoritative references.