

INDUSTRIAL INSPECTION REPORT

Facility: Plant-01

Equipment: Pump-03

Inspection Type: Contact Probe & Thermal Imaging

Observation: Pump-03 bearing temperature was observed at 92 degrees C.

Specification: Documented continuous operating limit is 80 degrees C.

Severity Context: High temperature condition requiring evaluation.