QRB power requirements & simulation

Objective

Specify high-level power system requirements and simulation of modular data centers in an electrical substation.

Background

QRB is deploying modular data centers for energy-intensive computation.
- Each module is a shipping container, loaded with 100-300 high power computers.
- The computers run on direct current 12V DC, drawing 3-4kW. They come with power supply units (PSUs) drawing 10-20A at 240V.
- Datacenter modules are deployed in electrical network substation compounds.
- Power supplied is AC 3-phase Δ configuration (3-wire) at 15kV, 50Hz.
- Transformer steps down to AC 240V Y config (4-wire): three 240V circuits plus neutral.
- Via switchboard, each circuit feeds 1/3 of the machines in the datacenter
- The machines are on shelves, each shelf is supplied by one power distribution unit (PDU)


1 modular data center

Single machine circuit model

A single machine (computer+PSU) can be modeled by the following circuit model
- PSU input :
  - 240V AC single phase
  - Power cord: AWG14 (2mm²), resistance 8.282 Ω/km
- Load:
  - 12V DC
  - Expect 3400W power consumption
  - Model the load as a pure resistance R_{load} = 12*12/3400 = 0.042 Ω.
- PSU simulation parameters:
  - N = 24 turns; resistance R_{PRI} = 0 Ω, R_{SEC} = 0.0012 Ω; inductance L = 1H; Capacitance C = 0.9F.
    Higher C => less "ripple" but lower power efficiency (more energy loss)
    Lower L => high current on primary and lower power efficiency.

Note: With these parameters, the efficiency (output/input power) of the simulated PSU is 48%. Real PSUs achieve 80-90% efficiency. Since we are calibrating the simulation to the output power (per machine consumption), the input power will be potentially overestimated by ~2x.

Single data center 3-phase power system (Δ-Y)

- Supply: f=50Hz, 3-phase 15kV
- Transmission: 700m x 150mm^2 All Aluminum Conductors - equiv to copper 2/0 AWG, 0.2555 Ω/km
- Transformer: delta-wye configuration step down transformer
- Delta primary: input amplitude is 15000√2 = 21,213V (line to line)
- Load per dc container: 240V single phase, 144 machines, 48 on each phase
- Load: 48 machines x 3.4kW each = 163.2kW per phase.
- PDU: one for every 12 machines
- Busbar in the data center: 50x15 mm, 23 µΩ/m
- Cables from busbar to PDUs: AWG2 (33.6mm^2), 0.513 Ω/km
- Transformer Rating: 2500 kVA
- Phase current Delta-Wye (see reference)
    - Primary phase current = line current/√3 = (2500/3)/(15√3)/√3 = 18.5A (rms) = 26.2A amplitude
    - Secondary phase current = line current = (2500/3)/(0.240√3) = 2005A (rms)   = 2835A amplitude

Transformer model parameters

Basic parameters

Windings ratio (for Delta-Wye, the ratio of line voltagesis √3 times greater than the nameplate ratio):

$$N = 15000/240 ≈ 62$$

Transformer Inductance (Delta-Wye):

$$L= (V/I)/2πf = (15000/18.5)/(2π*50) = 2.58H$$

Transformer load-loss (percent impedance)

- Data from actual 2500 kVA transformer
    - 20670/2500000=0.8% loss
    - 5.77% impedance voltage (percent of the rated primary voltage required to induce rated currents in both windings when secondary is shorted)
- Simulate with 5.77% of primary voltage (1224 V amplitude) and short circuit on secondary.
- Load-loss simulation circuit
- Adjust parameters so rated current in primary is approximately achieved (26.2A amplitude)

$$R_{pri} = 32 Ω$$

$$R_{sec} = 0.0038 \; \Omega$$

Transformer no-load loss (iron loss)

- [Data from actual 2500 kVA transformer](#)
    - 2253/2500000 = 0.1% loss
    - No load current 0.19%
- Simulate with 240V (339V amplitude) on secondary and open circuit on primary.
- [No-load loss simulation circuit](#)
- Adjust parameters to exciting current of 0.19% of rated = 2835*0.0019 = 5.39A amplitude achieved.

$$R\_c = 339/5.39 = 63\Omega$$

Data center module simulation

Equivalent circuit for 48 machines

A single data center module has 144 machines, 48 on each phase. Rather than simulating each machine individually, we can use an equivalent circuit for 48 machines. They are connected in parallel, so we want voltage to remain the same and current to be 48x. So in the equivalent circuit, we use the single machine values of R_{load} , R_{PRI} , R_{SEC} and L divided by 48, and C multiplied by 48.

QRB Labs

Simulation circuit

Input line voltage and current (one phase)

Transformer output voltages and currents (3-phases)

Transformer input and output power (one phase, sum of 3 phases) and core losses (sum of 3 phases)

Legend (top chart): ■ V(a)*I(Busbar_a.nA) ■ -(V(A.nA)-V(B.nA))*I(A.nA)

Legend (middle chart): ■ -(V(A.nA)-V(B.nA))*I(A.nA)-(V(B.nA)-V(C.nA))*I(B.nA)-(V(C.nA)-V(A.nA))*I(C.nA) ■ V(a)*I(Busbar_a.nA)+V(b)*I(Busbar_b.nA)+V(c)*I(Busbar_c.nA)

Legend (bottom chart): ■ I(Rc_A.nA)*V(a)+I(Rc_B.nA)*V(b)+I(Rc_C.nA)*V(c)

48 machine load voltage, current and power

Legend (top plot):
- V(PSU_out)
- I(Load11.nA)

Legend (bottom plot):
- V(PSU_out)*I(Load11.nA)

Simulation summary

Input voltage	15,004	V
Input current (per phase)	22	A
Input power (per phase)	309,096	W
Input power (sum of 3 phases)	624,217	W
Single data center module		
Data center input voltage	233	V
Data center input current (per phase)	977	A
Data center input power (one phase)	296,343	W
Data center input power (sum of 3 phases)	529,871	W
Load power (per 48 machines)	153,013	W