

PLANNED PREVENTIVE MAINTENANCE HOSPITAL TUANKU AZIZAH

YEAR: 2020

Update and verify inventory by checking and ticking boxes below

PPM:[]Q1[]Q2[]Q3[/]Q4

TYPE : [] Switch [/] UPS [] Firewall [] Load Balancer [] APs/Controller

Location: TCR L1.1

Model: Smart-UPS RT 3000 XL

Manufacture: APC

Serial Number : QS1606171173

A. PHYSICAL CHECK	
1.Cleaning	
a. Room	Yes
b. Rack	Yes
c. Equipment	Yes
2.Cable	
a. Tidiness	Yes
b. Labelling	Yes
3. Fan Condition	Yes
4. Check all LEDs and Port	Yes
5. Room Temperatur (Aircond)	
a. Temperature ()	Yes
6. Check UPS (Make sure UPS is connected properly and	Yes
functioning)	
7. PPM Tag	Yes
8. Device Tag	Yes
9. Power Over Ethernet	Yes
10. Free Port ()	No

D. UPS	
1. Output Load (33)	Yes
2. Battery Capacity (100)	Yes
3. Battery Temperature (27)	Yes
4. Run Time Remaining (3)	Yes
5. Replace Battery Indicator	Yes

Hostname: L01-1R1UPS1 Firmware Version: 5.2 IP Address: 10.12.200.52

Mac Address:

B.SETTING & CONFIGURATION	
1. Disable Unused Port	Yes
2. Memory Utilization	
a. (Memory Utilization : 33) 3. CPU Utilization	Yes
a. (CPU Utilization : 22)	Yes
4. Backup Configuration	Yes
5. Check VLAN SNMP (String)	
a. (SNMP String : ascdf)	Yes
6. Check VLAN	Yes
7. HA Status	
a. Online	Yes
b. Standby	Yes
8. Change Password	Yes

E. REMARK

SERVICED BY	VERIFIED BY	ENDORSED BY
Technical	Prohawk Staff	ITD staff
03/03/2021	03/03/2021	03/03/2021

NOTE: This PPM Form is computer generated and no signature is required