



### FOOTING NOTES:

- FOOTING RL'S ARE BASED ON A FFL OF RL 94.100. COORDINATE WITH FINAL ARCHITECTURAL/CIVIL DESIGN AND ADJUST AS REQUIRED OR REFER TO ENGINEER.
- TOP OF FOOTING LEVEL TO BE RL 93.850 TYPICAL U.N.O. ON PLAN
- ALL FOOTING LAYOUTS AND RL'S ARE FOR INFORMATION ONLY AND SHALL NOT BE USED FOR SETOUT PURPOSES. CONFIRM ALL DIMENSIONS WITH SHOP DETAILER.
- ALL FOOTING REINFORCEMENT TO HAVE MINIMUM 50mm CONCRETE COVER INCLUDING ANCHORS AND CAST-IN ITEMS, U.N.O.
- LOCALLY DEEPEN/WIDEN FOOTINGS AND/OR REFER TO ENGINEER AS REQUIRED.
- FOOTINGS TO BE FOUNDED 200 MIN. INTO NATURAL GROUND WITH MINIMUM ALLOWABLE BEARING CAPACITY AS NOTED IN GENERAL NOTES.
- DEEPEN FOOTINGS AS REQUIRED OR REFER TO ENGINEER.
- FOOTINGS DESIGNED FOR 100kPa ALLOWABLE BEARING CAPACITY TO BE FOUNDED 200 MINIMUM INTO LEVEL 1 CONTROLLED FILL.
- ALL STRUCTURAL STEELWORK TO BE CONCRETE ENCASED OR HAVE APPROPRIATE PROTECTION COATING IN ACCORDANCE WITH AS2312.1/2, PRIOR TO BACKFILLING. REFER TO STRUCTURAL STEEL NOTES.
- STRIP FOOTING REINFORCEMENT TO EXTEND 500 MIN. INTO PAD FOOTINGS