

SOP-OPS-002 Confined Space Entry

Revision C - Owner: Technical Services - Classification: Internal

1. Definition

A confined space is an enclosed space with limited entry or exit and not designed for continuous occupancy, for example vessels, columns, tanks and pits.

2. Atmosphere testing

Test in this order: oxygen, flammables, then toxics. Entry is allowed only when oxygen is 19.5 to 23.5 percent, flammables are below 1 percent LEL and H₂S is below 1 ppm.

3. Attendant

A standby attendant shall remain at the entry point at all times and shall never enter to attempt a rescue.

4. Rescue plan

A written rescue plan and rescue equipment shall be available before entry.