

STD-ENG-100 Instrument Tag and Line Numbering Convention

Revision C · Owner: Technical Services · Classification: Internal

1. Instrument tags

Instrument tags follow the pattern letters-number, for example PV-101, FT-2031, LT-305. The first letter is the measured variable: P pressure, F flow, L level, T temperature. The following letters give the function: T transmitter, I indicator, C controller, V valve, SV safety valve.

2. Numbering

The first digit of the number identifies the unit: 1 crude unit, 2 vacuum unit, 3 hydrotreater. PSVs use the prefix PSV, for example PSV-1204.

3. Line numbers

Line numbers follow size-service-number-class, for example 6"-P-1045-A1B, where P is process hydrocarbon and A1B is the piping class.