

KPI Quotidien

Interval From 01.07.2026 00:00

To 02.07.2026 00:00

Period Daily values

				Q1	25.06	26.06	27.06	28.06	29.06	30.06	01.07	FULL YEAR
				Target	JEUDI	VENDREDI	SAMEDI	DIMANCHE	LUNDI	MARDI	MERCREDI	BUDGET 2026
PLANT RESULTS LAGGING KPI	KPI	Unit										
FOUR B	CO2	Débit Bois	T/h	2		0.19	1.12	0.94	0.69	1.17	1.24	2
	PERFORMANCE	Débit Four	T/j	950	832	825	857	893	904	910	904	920
		Nb Arrêt Four	#	0	0	0	0	0	0	0	0	
		NAI Four	%		100.0	100.0	100.0	100.0	100.0	100.0	100.0	
		%KM HLC Utilisation	%	80	71.24			68.90	52.16	35.75	48.67	80
	ENERGY	STEC	MJ/t	5300	4588	4684	4631	4533	6364	7636	5532	5300
FOUR C	CO2	TSR	%	34	28.97	32.81	29.43	27.63	21.06	55.89	34.42	35,7%
		Débit DSB	T/h	2	1.32	1.34	1.34	1.20	1.47	1.05	1.75	1,9
		GAI	%	95	92.22	93.69	92.99	93.68	97.29	97.35	99.93	95,0%
		Débit FAN	T/h	2	2.48	2.29	2.42	2.17	2.07	1.05	1.47	1,9
		GAI	%	80	99.51	98.51	99.44	100.00	97.36	86.25	100.00	80,0%
		Débit Bois Amont	T/h	1,3	1.79	1.71	1.73	1.71	1.47	1.65	1.20	1,6
		GAI	%	90	100.00	99.57	100.00	100.00	24.51	67.34	100.00	90,0%
		Débit G2000	T/h	1,3	0.66	1.09	1.35	1.46	1.39	0.95	1.14	1,3
		Débit STEPI	T/h	0,5								0,5
	PERFORMANCE	Débit Four	T/j	1530	1433	1335	1428	1421	1452	1386	1484	1570 NORMAL 1470 HTS
		Nb Arrêt Four	#	0	0	1	0	0	0	1	0	
		NAI Four	%		100.0	97.9	100.0	100.0	100.0	99.5	100.0	
		%KM HLC Utilisation	%	60	37.15	38.97	39.35	31.04	38.99	30.57	28.50	80
	ENERGY	STEC	MJ/t	4074	4791	4744	4640	4631	4464	4015	4134	4050

BK BLANC	CO2	%CALCAIRE (CEM II 52,5)	%	7,2	8.3	8.6	8.3	8.4	8.6	8.2	8.2	7,2%
	PERFORMANCE	Nombre d'arrêts BK15	nbre	1	2	1	2	1	0	2	1	0
	MONITORING	%DOUTEUX BK15	%	5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	5%
BK GRIS	CO2	%AJOUTS à la cible du produit	%	29,9								29,9%
	PERFORMANCE	Nombre d'arrêts BK0	nbre	1	0	1	0	2	0	3	1	
		Nombre d'arrêts BK1	nbre	1	0	2	1	0	0	1	1	
	MONITORING	%DOUTEUX BK0	%	30	10.5	10.6	19.6	20.7	19.9	1.4	0.4	20
		%DOUTEUX au BK1	%	30	0.0	0.0	0.0			0.0	0.0	20
		%DOUTEUX Dilution	%	8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	8%