

KPI Quotidien

Interval From 08.07.2026 00:00

To 09.07.2026 00:00

Period Daily values

				Q1	02.07	03.07	04.07	05.07	06.07	07.07	08.07	FULL YEAR
PLANT RESULTS LAGGING KPI				Target	JEUDI	VENDREDI	SAMEDI	DIMANCHE	LUNDI	MARDI	MERCREDI	BUDGET 2026
FOUR B	CO2	Débit Bois	T/h	2	0.74	0.54	1.15	0.50	0.61	1.02	1.59	2
	PERFORMANCE	Débit Four	T/j	950	866	827	872	894	866	889	884	920
		Nb Arrêt Four	#	0	2	0	0	0	0	0	0	
		NAI Four	%		100.0	100.0	100.0	100.0	100.0	100.0	100.0	
		%KM HLC Utilisation	%	80	50.76	55.93	36.45	64.34			25.55	80
	ENERGY	STEC	MJ/t	5300	5997	6221	5625	5556	5644	5497	5441	5300
FOUR C	CO2	TSR	%	34	76.80	77.08	28.87	28.11	26.00	58.76	31.69	35,7%
		Débit DSB	T/h	2	1.86	1.63	1.61	1.67	1.65	1.58	1.96	1,9
		GAI	%	95	87.50	80.14	99.51	99.10	94.70	90.81	95.42	95,0%
		Débit FAN	T/h	2	1.16	1.54	1.50	1.50	1.79	1.51	1.94	1,9
		GAI	%	80	77.85	100.00	100.00	100.00	100.07	85.74	100.00	80,0%
		Débit Bois Amont	T/h	1,3	1.20	1.14	1.00	0.99	1.08	1.04	1.39	1,6
		GAI	%	90	100.00	100.00	97.15	100.00	75.11	94.75	100.00	90,0%
		Débit G2000	T/h	1,3	1.03	1.20	1.24	1.30	1.28	0.36	1.40	1,3
		Débit STEPI	T/h	0,5								0,5
	PERFORMANCE	Débit Four	T/j	1530	1424	1463	1564	1506	1463	497	1499	1570 NORMAL 1470 HTS
		Nb Arrêt Four	#	0	0	0	0	0	1	1	0	
		NAI Four	%		100.0	100.0	100.0	100.0	98.2	37.0	100.0	
		%KM HLC Utilisation	%	60	36.69	28.99	37.10	38.83	15.48	24.90	36.14	80
	ENERGY	STEC	MJ/t	4074	4052	3924	4068	4084	4138	6220	4277	4050

BK BLANC	CO2	%CALCAIRE (CEM II 52,5)	%	7,2		8.1	8.1	8.6	8.4	8.3	8.2	7,2%
	PERFORMANCE	Nombre d'arrêts BK15	nbre	1	2	1	0	0	1	1	5	0
	MONITORING	%DOUTEUX BK15	%	5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	5%
BK GRIS	CO2	%AJOUTS à la cible du produit	%	29,9								29,9%
	PERFORMANCE	Nombre d'arrêts BK0	nbre	1	1	2	0	0	0	3	3	
		Nombre d'arrêts BK1	nbre	1	6	1	0	0	0	1	0	
	MONITORING	%DOUTEUX BK0	%	30	7.9	18.2	18.8	20.0	18.5	17.2	14.0	20
		%DOUTEUX au BK1	%	30	0.0	0.0	0.0	0.0	0.0	0.0	0.0	20
		%DOUTEUX Dilution	%	8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	8%