

KPI Quotidien

Interval From 17.09.2026 00:00

To 18.09.2026 00:00

Period Daily values

				Q1	11.09	12.09	13.09	14.09	15.09	16.09	17.09	FULL YEAR
PLANT RESULTS LAGGING KPI				Target	VENDREDI	SAMEDI	DIMANCHE	LUNDI	MARDI	MERCREDI	JEUDI	BUDGET 2026
FOUR B	CO2	Débit Bois	T/h	2	0.00							2
	PERFORMANCE	Débit Four	T/j	950							776	920
		Nb Arrêt Four	#	0	0	0	0	0	0	0	1	
		NAI Four	%		100.0	100.0	100.0	100.0	100.0	100.0	77.4	
		%KM HLC Utilisation	%	80	0.00							80
	ENERGY	STEC	MJ/t	5300							67126	5300
FOUR C	CO2	TSR	%	34	24.49	32.19	31.67	29.57	34.95	44.50	41.78	35,7%
		Débit DSB	T/h	2	1.34	1.57	1.79	1.81	1.74	1.87	1.53	1,9
		GAI	%	95	78.47	90.98	100.00	99.93	85.14	97.01	66.81	95,0%
		Débit FAN	T/h	2	1.76	1.67	1.77	1.91	1.88	2.00	2.00	1,9
		GAI	%	80	91.25	70.97	98.82	100.00	99.44	100.00	100.00	80,0%
		Débit Bois Amont	T/h	1,3	1.05	1.19	1.20	1.20	1.20	1.20	1.20	1,6
		GAI	%	90	100.00	98.75	100.00	100.00	100.00	97.43	100.00	90,0%
		Débit G2000	T/h	1,3	1.40	1.22	1.29	0.90	0.07			1,3
		Débit STEPI	T/h	0,5								0,5
	PERFORMANCE	Débit Four	T/j	1530	1611	1491	1527	1554	1435	1403	1494	1570 NORMAL 1470 HTS
		Nb Arrêt Four	#	0	0	1	0	0	0	0	0	
		NAI Four	%		100.0	94.7	100.0	100.0	100.0	100.0	100.0	
		%KM HLC Utilisation	%	60	42.35	31.35	38.77	40.00	22.92	29.29	32.49	80
	ENERGY	STEC	MJ/t	4074	4211	4328	4356	4342	4348	4269	4028	4050

BK BLANC	CO2	%CALCAIRE (CEM II 52,5)	%	7.2	8.2	8.2	8.5	8.3	8.0	7.9	8.4	7,2%
	PERFORMANCE	Nombre d'arrêts BK15	nbre	1	3	6	0	0	2	2	8	0
	MONITORING	%DOUTEUX BK15	%	5	0.5	0.0			1.3	0.0	4.9	5%
BK GRIS	CO2	%AJOUTS à la cible du produit	%	29,9								29,9%
	PERFORMANCE	Nombre d'arrêts BK0	nbre	1	2	0	0	2	0	2	1	
		Nombre d'arrêts BK1	nbre	1	1	0	1	1	0	2	2	
	MONITORING	%DOUTEUX BK0	%	30	16.3	18.1	17.9	21.9		20.5	22.2	20
		%DOUTEUX au BK1	%	30	2.7	0.0	0.0	0.0	0.0	13.3	13.3	20
		%DOUTEUX Dilution	%	8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	8%