

KPI Quotidien

Interval From 14.05.2026 00:00

To 15.05.2026 00:00

Period Daily values

				Q1	08.05	09.05	10.05	11.05	12.05	13.05	14.05	FULL YEAR
PLANT RESULTS LAGGING KPI				Target	VENDREDI	SAMEDI	DIMANCHE	LUNDI	MARDI	MERCREDI	JEUDI	BUDGET 2026
FOUR B	CO2	Débit Bois	T/h	2	0.47	0.83	0.72	0.01	0.15	1.06	1.04	2
	PERFORMANCE	Débit Four	T/j	950	898	878	847	812	774	835	823	920
		Nb Arrêt Four	#	0	0	0	0	2	1	0	0	
		NAI Four	%		100.0	100.0	100.0	71.4	46.2	100.0	100.0	
		%KM HLC Utilisation	%	80	72.60	71.02		55.37				80
	ENERGY	STEC	MJ/t	5300	5402	5458	5511	6014	7449	5575	5722	5300
FOUR C	CO2	TSR	%	34	62.97	39.11	22.17	141.42	23.57	34.96	53.04	35,7%
		Débit DSB	T/h	2	2.03	1.53	1.46	1.04	1.32	1.67	1.86	1,9
		GAI	%	95	100.00	91.32	73.66	61.10	91.53	98.68	99.79	95,0%
		Débit FAN	T/h	2	1.82	1.77	0.88	1.18	1.68	1.67	1.50	1,9
		GAI	%	80	97.08	100.00	100.23	65.72	100.00	89.72	93.26	80,0%
		Débit Bois Amont	T/h	1,3	1.00	1.00	1.06	0.70	0.94	1.10	0.98	1,6
		GAI	%	90	100.00	100.00	100.00	36.77	100.00	99.38	65.83	90,0%
		Débit G2000	T/h	1,3	1.00	1.00	0.30		0.63	1.40	1.40	1,3
		Débit STEPI	T/h	0,5								0,5
	PERFORMANCE	Débit Four	T/j	1530	1359	1366	405	497	1423	1503	1509	1570 NORMAL 1470 HTS
		Nb Arrêt Four	#	0	0	0	1	1	0	0	0	
		NAI Four	%		100.0	100.0	29.8	39.1	100.0	100.0	100.0	
		%KM HLC Utilisation	%	60	21.75	18.14	15.09	5.18	16.92	34.92	46.22	80
	ENERGY	STEC	MJ/t	4074	4320	4315	4312	6555	4175	4151	3965	4050

BK BLANC	CO2	%CALCAIRE (CEM II 52,5)	%	7.2	7.7	7.8	7.7	7.5	7.7	7.7	7.8	7,2%
	PERFORMANCE	Nombre d'arrêts BK15	nbre	1	1	0	2	1	0	1	1	0
	MONITORING	%DOUTEUX BK15	%	5	0.0	0.0	0.0	0.0		0.1	0.0	5%
BK GRIS	CO2	%AJOUTS à la cible du produit	%	29,9								29,9%
	PERFORMANCE	Nombre d'arrêts BK0	nbre	1	1	1	2	2	1	2	0	
		Nombre d'arrêts BK1	nbre	1	4	0	0	0	2	2	1	
	MONITORING	%DOUTEUX BK0	%	30	21.6	21.9	14.9	13.1	7.5	21.7	19.3	20
		%DOUTEUX au BK1	%	30	0.0				0.0	0.0	0.0	20
		%DOUTEUX Dilution	%	8	0.0	0.1	0.0	0.0	0.0	0.0	0.0	8%