

KPI Quotidien

Interval From 22.05.2026 00:00

To 23.05.2026 00:00

Period Daily values

				Q1	16.05	17.05	18.05	19.05	20.05	21.05	22.05	FULL YEAR
				Target	SAMEDI	DIMANCHE	LUNDI	MARDI	MERCREDI	JEUDI	VENDREDI	BUDGET 2026
FOUR B	PLANT RESULTS LAGGING KPI	KPI	Unit									
	CO2	Débit Bois	T/h	2	1.10				0.12	0.10	0.03	2
	PERFORMANCE	Débit Four	T/j	950	843	841	833	841	830	824	837	920
		Nb Arrêt Four	#	0	0	0	0	1	0	0	0	
		NAI Four	%		100.0	100.0	100.0	93.6	100.0	100.0	100.0	
		%KM HLC Utilisation	%	80					38.64			80
FOUR C	ENERGY	STEC	MJ/t	5300	5778	5712	5697	5711	5729	5741	5622	5300
	CO2	TSR	%	34	33.06	43.31	38.81	100.00	58.34	42.93	42.60	35,7%
		Débit DSB	T/h	2	1.78	1.57	1.78		1.42	2.00	2.00	1,9
		GAI	%	95	97.22	96.46	94.03		83.18	100.00	100.55	95,0%
		Débit FAN	T/h	2	1.40	1.72	1.82		1.40	1.90	2.00	1,9
		GAI	%	80	100.00	100.00	66.69		82.65	91.60	100.55	80,0%
		Débit Bois Amont	T/h	1,3	1.31	1.00	1.06		1.09	1.27	1.30	1,6
		GAI	%	90	54.65	54.72	76.56		68.07	99.58	100.00	90,0%
		Débit G2000	T/h	1,3	1.40	1.40	1.37		0.53	1.40	0.18	1,3
		Débit STEPI	T/h	0,5								0,5
	PERFORMANCE	Débit Four	T/j	1530	1595	1575	1571	0	753	1660	211	1570 NORMAL 1470 HTS
		Nb Arrêt Four	#	0	0	0	1	0	0	0	1	
		NAI Four	%		100.0	100.0	97.8	0.0	52.8	100.0	12.6	
		%KM HLC Utilisation	%	60	44.29	44.67	46.40	0.00	31.48	40.22	66.18	80
	ENERGY	STEC	MJ/t	4074	3868	3921	3902		5584	4059	4108	4050

BK BLANC	CO2	%CALCAIRE (CEM II 52,5)	%	7.2	8.1	8.4	8.4	7.9	7.8	7.9	8.2	7,2%
	PERFORMANCE	Nombre d'arrêts BK15	nbre	1	1	0	0	0	1	0	1	0
	MONITORING	%DOUTEUX BK15	%	5	0.0			0.0	0.0	0.0	0.0	5%
BK GRIS	CO2	%AJOUTS à la cible du produit	%	29,9								29,9%
	PERFORMANCE	Nombre d'arrêts BK0	nbre	1	1	1	0	0	2	0	1	
		Nombre d'arrêts BK1	nbre	1	1	0	0	1	2	1	3	
	MONITORING	%DOUTEUX BK0	%	30	10.4	20.0	22.0	13.6	21.4	18.6	17.3	20
		%DOUTEUX au BK1	%	30	0.0	0.0	0.0	0.0	19.5	19.8	20.0	20
		%DOUTEUX Dilution	%	8	0.0	0.0	0.0	0.0	0.1	0.0	0.0	8%