

KPI Quotidien

Intervalle de 05.07.2026 00:00

à 06.07.2026 00:00

Période Daily values

				Q1	29.06	30.06	01.07	02.07	03.07	04.07	05.07	FULL YEAR
	PLANT RESULTS LAGGING KPI	KPI	Unit	Target	LUNDI	MARDI	MERCREDI	JEUDI	VENDREDI	SAMEDI	DIMANCHE	BUDGET 2026
FOUR B	CO2	Débit Bois	T/h	2	0.69	1.17	1.24	0.74	0.54	1.15	0.50	2
	PERFORMANCE	Débit Four	T/j	950	904	910	904	866	827	872	894	920
		Nb Arrêt Four	#	0	0	0	0	2	0	0	0	
		NAI Four	%		100.0	100.0	100.0	71.9	78.8	100.0	100.0	
		%KM HLC Utilisation	%	80	52.16	35.75	48.67	50.76	55.93	36.45	64.34	80
	ENERGY	STEC	MJ/t	5300	6364	7636	5532	5997	6221	5625	5556	5300
FOUR C	CO2	TSR	%	34	21.06	55.89	34.42	76.80	77.08	28.87	28.11	35,7%
		Débit DSB	T/h	2	1.47	1.05	1.75	1.86	1.63	1.61	1.67	1,9
		GAI	%	95	97.29	97.35	99.93	87.50	80.14	99.51	99.10	95,0%
		Débit FAN	T/h	2	2.07	1.05	1.47	1.16	1.54	1.50	1.50	1,9
		GAI	%	80	97.36	86.25	100.00	77.85	100.00	100.00	100.00	80,0%
		Débit Bois Amont	T/h	1,3	1.47	1.65	1.20	1.20	1.14	1.00	0.99	1,6
		GAI	%	90	24.51	67.34	100.00	100.00	100.00	97.15	100.00	90,0%
		Débit G2000	T/h	1,3	1.39	0.95	1.14	1.03	1.20	1.24	1.30	1,3
		Débit STEPI	T/h	0,5								0,5
	PERFORMANCE	Débit Four	T/j	1530	1452	1386	1484	1424	1463	1564	1506	1570 NORMAL 1470 HTS
		Nb Arrêt Four	#	0	0	1	0	0	0	0	0	
		NAI Four	%		100.0	99.5	100.0	100.0	100.0	100.0	100.0	
		%KM HLC Utilisation	%	60	38.99	30.57	28.50	36.69	28.99	37.10	38.83	80
	ENERGY	STEC	MJ/t	4074	4464	4015	4134	4052	3924	4068	4084	4050

BK BLANC	CO2	%CALCAIRE (CEM II 52,5)	%	7,2	8.6	8.2	8.2		8.1	8.1	8.6	7,2%
	PERFORMANCE	Nombre d'arrêts BK15	nbre	1	0	2	1	2	1	0	0	0
	MONITORING	%DOUTEUX BK15	%	5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	5%
BK GRIS	CO2	%AJOUTS à la cible du produit	%	29,9								29,9%
	PERFORMANCE	Nombre d'arrêts BK0	nbre	1	0	3	1	1	2	0	0	
		Nombre d'arrêts BK1	nbre	1	0	1	1	6	1	0	0	
	MONITORING	%DOUTEUX BK0	%	30	19.9	1.4	0.4	7.9	18.2	18.8	20.0	20
		%DOUTEUX au BK1	%	30		0.0	0.0	0.0	0.0	0.0	0.0	20
		%DOUTEUX Dilution	%	8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	8%