

KPI Quotidien

Interval From 14.09.2026 00:00

To 15.09.2026 00:00

Period Daily values

				Q1	08.09	09.09	10.09	11.09	12.09	13.09	14.09	FULL YEAR
PLANT RESULTS LAGGING KPI				Target	MARDI	MERCREDI	JEUDI	VENDREDI	SAMEDI	DIMANCHE	LUNDI	BUDGET 2026
FOUR B	CO2	Débit Bois	T/h	2				0.00				2
	PERFORMANCE	Débit Four	T/j	950								920
		Nb Arrêt Four	#	0	0	0	0	0	0	0	0	
		NAI Four	%		100.0	100.0	100.0	100.0	100.0	100.0	100.0	
		%KM HLC Utilisation	%	80				0.00				80
	ENERGY	STEC	MJ/t	5300								5300
FOUR C	CO2	TSR	%	34	62.92	69.05	31.49	24.49	32.19	31.67	29.57	35,7%
		Débit DSB	T/h	2	1.56	1.64	1.75	1.34	1.57	1.79	1.81	1,9
		GAI	%	95	91.61	99.93	95.00	78.47	90.98	100.00	99.93	95,0%
		Débit FAN	T/h	2	1.66	1.78	1.67	1.76	1.67	1.77	1.91	1,9
		GAI	%	80	98.15	99.65	51.94	91.25	70.97	98.82	100.00	80,0%
		Débit Bois Amont	T/h	1,3	1.02	1.20	1.20	1.05	1.19	1.20	1.20	1,6
		GAI	%	90	98.83	100.00	100.00	100.00	98.75	100.00	100.00	90,0%
		Débit G2000	T/h	1,3	0.38	1.26	1.40	1.40	1.22	1.29	0.90	1,3
		Débit STEPI	T/h	0,5								0,5
	PERFORMANCE	Débit Four	T/j	1530	530	1313	1517	1611	1491	1527	1554	1570 NORMAL 1470 HTS
		Nb Arrêt Four	#	0	0	0	0	0	1	0	0	
		NAI Four	%		41.4	100.0	100.0	100.0	94.7	100.0	100.0	
		%KM HLC Utilisation	%	60	50.59	59.72	53.28	42.35	31.35	38.77	40.00	80
	ENERGY	STEC	MJ/t	4074	6089	4544	4303	4211	4328	4356	4342	4050

BK BLANC	CO2	%CALCAIRE (CEM II 52,5)	%	7,2	8.0	7.9	8.3	8.2	8.2	8.5	8.3	7,2%
	PERFORMANCE	Nombre d'arrêts BK15	nbre	1	1	3	2	3	6	0	0	0
	MONITORING	%DOUTEUX BK15	%	5	0.0	0.9	0.6	0.5	0.0			5%
BK GRIS	CO2	%AJOUTS à la cible du produit	%	29,9								29,9%
	PERFORMANCE	Nombre d'arrêts BK0	nbre	1	1	2	0	2	0	0	2	
		Nombre d'arrêts BK1	nbre	1	2	1	0	1	0	1	1	
	MONITORING	%DOUTEUX BK0	%	30	12.8	12.2	19.7	16.3	18.1	17.9	21.9	20
		%DOUTEUX au BK1	%	30	0.0	0.0	10.8	2.7	0.0	0.0	0.0	20
		%DOUTEUX Dilution	%	8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	8%