# PUNE MUNICIPAL CORPORATION · CHIEF FIRE OFFICER

FIRE SAFETY CERTIFICATE / NO OBJECTION CERTIFICATE (NOC)

## CERTIFICATE SPECIFICATIONS

| | | |
|---|---|---|
| Fire NOC No | : | PMC/FIRE/NOC/2024/7821 |
| Certificate No | : | FSNO-MH-2024-89214 |
| Date of Issue | : | 10/01/2024 |
| Valid Till | : | 31/12/2025 |
| Classification | : | Fire Safety Certificate / Educational Occupancy NOC |

## INSPECTED PREMISES

| | | |
|---|---|---|
| Name of Institution | : | Sunrise Institute of Technology |
| Institution Name | : | Sunrise Institute of Technology |
| Address | : | Survey No. 45, Baner Road, Pune - 411045, Maharashtra |
| Total Built-up Area | : | 18,500 Sqm (Ground + 3 Upper Floors) |
| Authority | : | Chief Fire Officer, Pune Municipal Corporation |
| Issued by | : | Chief Fire Officer, PMC, Pune |
| Fire Officer | : | Shri A.K. Patil, Chief Fire Officer |

## FIRE SAFETY COMPLIANCE DETERMINATION

1. Fire Hydrant System, Wet Risers, and Hose Reels tested and certified functional.
2. Underground Static Water Tank (100,000 Litres) and Overhead Tanks verified operational.
3. Automatic Smoke Detection and Alarm System installed across all laboratories and corridors.
4. Emergency Exits, Fire Doors, and Staircase enclosures verified as per NBC 2016 standards.
5. Certified in compliance with the Maharashtra Fire Prevention and Life Safety Measures Act.