# FIRE SAFETY NO OBJECTION CERTIFICATE (NOC)

DIRECTORATE OF MAHARASHTRA FIRE SERVICES
Pune Municipal Corporation Fire Brigade Headquarters

Fire NOC Reference No: PMC/FB/NOC/2024/9912
Certificate No: FSNO-MH-2024-78219
Name of Institution: Sunrise Institute of Technology (DEMO)
Address: Survey No. 45, Baner Road, Pune - 411045

This is to certify that the campus premises of Sunrise Institute of Technology (DEMO) have been inspected by the Chief Fire Officer under the Maharashtra Fire Prevention and Life Safety Measures Act, 2006.
The premises are equipped with active and passive fire protection systems including:
- 2,00,000 Litres underground dedicated fire static water storage tank
- 20,000 Litres overhead terrace booster tank with automatic jockey pumps
- Complete wet riser, external yard hydrants, and hose reel system covering all floors
- Automatic addressable smoke and heat detection system in laboratories and server rooms
- Dual fire escape staircases with width > 2.0 meters conforming to NBC Part IV

Issue Date: 10/01/2024
Valid Till: 31/12/2028
Issued by: Chief Fire Officer, Pune Municipal Corporation Fire Brigade
Authority: Chief Fire Officer, PMC, Pune