MADHUMATHIDATTA
SUSTAINABILITY SERVICES PVT. LTD.
ESG • BRSR • GHG • Net Zero • Carbon Neutral Assurance • Energy Audits

Badhe House, 6-3-788/36 & 35A, Durganager,
Ameerpet, Hyderabad – 500016, Telangana, India
T +91 83338 26183
E rageshjoshi@mdsspl.com
W www.mdsspl.com

Finding Report (CAR / CR / FAR)

Document No.	MDSSPL-ZLD-R0003	Rev.	1.0	Issue Date	05 NOV 2026	Approved	Director
Service	Zero Liquid Discharge (Service code ZLD)					Service Group	Energy, water and waste

Engagement details			
Client / Organization		Engagement Ref.	
Site(s) / Boundary		Verification Type	☐ Initial ☐ Surveillance / Re-verification ☐ Follow-up
Criteria / Standards	☐ CTO / EC ZLD conditions ☐ CPCB / SPCB norms ☐ ISO 5667 sampling ☐ IS 3025 testing ☐ ISO/IEC 17025 lab ☐ ISO 14001 ☐ Other [ ]		
Verification Period		Facility / Gate Boundary	
Treatment Train	☐ ETP ☐ STP ☐ RO ☐ MEE ☐ ATFD / Crystalliser		
Lead Verification		Date of Finding	

Finding			
Finding No.		Date Raised	
Type of Finding	☐ CAR – Corrective Action Request ☐ CR – Clarification Request ☐ FAR – Forward Action Request		
Category	☐ Critical ☐ Major ☐ Minor ☐ Concern		
Nature of Finding	☐ Effluent balance discrepancy ☐ Discharge / regulatory non-compliance ☐ Treatment / monitoring deficiency		
Balance Node	☐ Intake ☐ ETP / STP ☐ RO / MEE ☐ Reuse / Utilisation ☐ Gate / Outfall	Meter / Sampling Point	
Quantity Affected (kL/day)		% of Effluent Generated	

Description of finding		
Detail of finding		
Objective evidence (documents, records, data sampled, site observations)		
Requirement (quote the applicable clause / requirement)		
Clause reference	*Select from the lists below; add other criteria in the last row.*	
ZLD Requirements	– Select –	– Select –
ISO 14001:2015	– Select –	
Other criteria / ref.		

Lead Verifier		Auditee Representative	
Date		Date	

Response by the client			
Root cause			
Correction (immediate)			
Corrective action			
Corrected effluent balance (kL/day)			
Proposed completion date		**Submitted by / Date**	

Review and closure by MDSSPL			
Acceptance of root cause and correction	☐ Accepted ☐ Not accepted Comments:		
Verification of corrective action			
Finding status	☐ Open ☐ Closed ☐ Carried forward as FAR ☐ Affects ZLD certificate		
Lead Verifier signature		**Date of closure**	

Annex A – Zero Liquid Discharge Requirement Areas

Clause / Ref.	Title / Requirement
Zero Liquid Discharge – requirement areas	
ZLD	Consent to Operate (CTO) / Environmental Clearance ZLD conditions
ZLD	CPCB / SPCB ZLD directions and guidelines
ZLD	Plant boundary and company gate (no discharge outside the gate)
ZLD	Flow meters at intake, ETP, RO, MEE, recycle and use points
ZLD	Water and effluent balance closure
ZLD	ETP / STP performance and treated-water quality
ZLD	RO reject, MEE and ATFD / crystalliser operation
ZLD	Reuse and utilisation of treated water
ZLD	Salt and sludge storage and disposal to authorised TSDF / co-processor
ZLD	Online monitoring (OCEMS) and data connectivity
ZLD	Stormwater segregation and outfall closure
ZLD	Laboratory testing (ISO/IEC 17025 lab), sampling per ISO 5667 / IS 3025

Annex B – ISO 14001:2015 Clause Reference

Clause / Ref.	Title / Requirement
ISO 14001:2015 – Environmental management systems	
4.1	Understanding the organization and its context
4.2	Needs and expectations of interested parties
4.3	Scope of the EMS
4.4	Environmental management system
5.1	Leadership and commitment
5.2	Environmental policy
5.3	Organizational roles, responsibilities and authorities
6.1.2	Environmental aspects
6.1.3	Compliance obligations
6.1.4	Planning action
6.2	Environmental objectives and planning to achieve them
7.1	Resources
7.2	Competence
7.3	Awareness
7.4	Communication
7.5	Documented information
8.1	Operational planning and control
8.2	Emergency preparedness and response
9.1.1	Monitoring, measurement, analysis and evaluation
9.1.2	Evaluation of compliance
9.2	Internal audit
9.3	Management review
10.2	Nonconformity and corrective action
10.3	Continual improvement

Annex C – Finding Types and Categories

Term	Meaning
CAR	Corrective Action Request: a misstatement or non-conformity that must be corrected and closed before a positive conclusion, opinion, certificate or claim can be issued.
CR	Clarification Request: information is insufficient or unclear to decide whether a requirement is met; the client must provide clarification or evidence.
FAR	Forward Action Request: an issue to be addressed and checked in the next period; it does not prevent the current conclusion.
Effluent balance discrepancy	Metered intake, treatment, recycle and utilisation flows do not reconcile.
Discharge / regulatory non-compliance	Any effluent leaves the gate or a consent / CPCB / SPCB condition is not met.
Treatment / monitoring deficiency	Treatment units, meters, sampling or laboratory testing do not support the ZLD claim.
Critical	Finding that alone makes the reported information materially wrong or prevents a conclusion; immediate correction required.
Major	Systematic or significant failure that could lead to a material error or invalid claim if not corrected.
Minor	Isolated lapse not likely to cause a material error or invalid claim on its own.
Concern	Observation or opportunity for improvement; no action is mandatory.

Severity categories are suggested definitions aligned with MDSSPL procedures. Clause titles are summarized for reference; refer to the licensed standards and current regulatory texts for full requirements.