

WATER QUALITY TEST REPORT

Report Issued Date: 10/09/2026

Report Number: 000105

Sample Particulars: RO Water

Test Results:

pH Value: 7.63 (Acceptable: 6.5 - 8.5)

Total Dissolved Solids: 163 mg/l (Acceptable Limit: 500)

Turbidity: 0.6 (Acceptable Limit: 1)

Total Hardness: 43.2 mg/l (Acceptable Limit: 200)

Remark: The above given sample conforms Acceptable Limit, as per IS10500:2012 For The above tested parameters only