



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
WATER QUALITY TESTING LABORATORY YADGIR
 Railway Station Road Near Railway Station, Yadgir-585-202
 Email ID: rdwsd.wqmstp.yadgirlab@gmail.com



TC-11626

WATER QUALITY TEST REPORT

To,

**The President
 Dr. Veerabhadra Gouda Hosamani
 Ashirwad Global HPS, Isampur Cross,
 Kembhavi Road, Hunasagi
 Karnataka -585215**

Report Issued Date: 10/09/2026
ULR No: TC -16893-202600001856F
Report Number: 000105
Sample code: YDG26SEP000105
Sample receipt date: 09/09/2026
Date of Sample collection: 09/09/2026
Analysis starts date: 09/09/2026
Analysis completion date: 10/09/2026
Environmental Condition: 25±5
Sample collection protocol: IS 10500 :2012

Sample Particulars: RO Water

Sample Quantity: 1 Liter

Sl. No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Test Method
Description: Clear Sample					
1.	pH Value @25.4° C	7.63	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2.	Specific Conductance, µS/cm	201	—	—	IS 3025 (Part-14) : 2023
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5) :2018
4.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8):2018
5.	Colour, Hazen Units	05	5	15	IS 3025 (Part-4) :2021
6.	Turbidity, NTU	0.6	1	5	IS 3025 (Part-10) :2023
7.	Total Dissolved Solids @ 105°C, mg/l	163	500	2000	IS 3025 (Part-16) : 2023
8.	Alkalinity as CaCO ₃ , mg/l	34.8	200	600	IS 3025 (Part-23) : 2023
9.	Total Hardness as CaCO ₃ , mg/l	43.2	200	600	IS 3025 (Part-21) : 2009
10.	Calcium as Ca, mg/l	08.5	75	200	IS 3025 (Part-40) : 2024
11.	Magnesium as Mg, mg/l	04	30	100	IS 3025 (Part-46) : 2023
12.	Chloride as Cl, mg/l	32.7	250	1000	IS 3025 (Part-32) : 1988
13.	Sulphate as SO ₄ , mg/l	36	200	400	IS 3025 (Part-24) : 2022
14.	Fluoride as F, mg/l	0.062	1	1.5	APHA 24 rd Edition
15.	Nitrate as NO ₃ , mg/l	03	45	No relaxation	APHA 24 rd Edition
16.	Iron as Fe, mg/l	0.01	1	No relaxation	IS 3025 (Part-53) : 2024

Remark: The above given sample conforms Acceptable Limit, as per IS10500:2012 For The above tested parameters only

Analyzed by: Ravikumar

Authorized Signatory: [Signature]

Senior Analyst / Junior Analyst

Technical Manager (Ravikumar)

Senior Analyst
 RDWSD/WQMSP/TR//01
 RDW&S Division Lab Yadgir

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced or copied in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurement results is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01.

