

TEST SUMMARY

Date: 11/01/2026 16:04


Test Company ROPECENTRIC LLC

Name of Tester: admin

Client Name: Demo Client

Signed:

Site Name: Demo Site

A handwritten signature in black ink, slanted upwards from left to right, positioned to the right of the 'Signed:' label.

FL01

11/01/2026 16:04

Tester	Email	Company	Telephone
admin	admin@ropecentric.com	ROPECENTRIC LLC	

SITE		CLIENT	
Name	Demo Site	Name	Demo Client
Address	123 A Street, A City, A County, United Kingdom, PO57 C0D3	Address	123 A Street, A City, A County, United Kingdom, PO57 C0D3
Contact	Site Contact	Contact	Client Contact
Email	no-reply@hydrajaws.co.uk	Email	no-reply@hydrajaws.co.uk
Telephone	+44 123 456 7890	Telephone	+44 123 456 7890

BOLT HANGER (CONCRETE)-3/8"

Category	Substrate	Fixing Type	Size	Manufacturer	Part Number	Component	Type
Fixing / Anchor / Construction Eyebolt	Concrete	Mechanical	3/8" - 16 UNC	Simpson Strong Tie 2	STB2-37313S6F50		Proof Test

Task Results:

1 Tests
1 Passed
0 Failed

Mechanical 1 (Equipment: MAN9916 25kN, Calibration Expiry: 23-Apr-2026 04:00)





Duration	Total Time	Target Load	Load Achieved	Displacement	Reference	Result
2 mins	163 secs	7.5kN	8kN		F1NRAYURBGANCK	Passed

Air Temperature: 59°F

Longitude:

Latitude:

Test Date: 11/01/2026 16:04



Mechanical 1
Test images:

