

Inspection Report INS001

SYNTHETIC TRAINING DATA - NOT FOR OPERATIONAL OR LEGAL USE

Plant	Sahyadri Process Chemicals Plant
Date	2025-08-01
Equipment	P104 - Process Pump P104
Inspection Type	Visual
Inspector Id	EMP001

Observed Condition

No significant defect

Measurements

- Vibration: 2.7 mm/s RMS
- Bearing temperature: 63 deg C
- Guarding and identification: satisfactory

Result

Pass

Recommendation

Continue routine monitoring

Follow-up

Linked work order: None required