

Inspection Report INS002

SYNTHETIC TRAINING DATA - NOT FOR OPERATIONAL OR LEGAL USE

Plant	Sahyadri Process Chemicals Plant
Date	2025-08-15
Equipment	P109 - Process Pump P109
Inspection Type	Vibration
Inspector Id	EMP008

Observed Condition

Early bearing wear trend

Measurements

- Vibration: 3.4 mm/s RMS
- Bearing temperature: 68 deg C
- Guarding and identification: satisfactory

Result

Monitor

Recommendation

Raise corrective work order and re-inspect

Follow-up

Linked work order: WO022