

Inspection Report INS003

SYNTHETIC TRAINING DATA - NOT FOR OPERATIONAL OR LEGAL USE

Plant	Sahyadri Process Chemicals Plant
Date	2025-08-29
Equipment	P114 - Process Pump P114
Inspection Type	Thermography
Inspector Id	EMP015

Observed Condition

Hot terminal detected

Measurements

- Vibration: 4.1 mm/s RMS
- Bearing temperature: 73 deg C
- Guarding and identification: satisfactory

Result

Action Required

Recommendation

Raise corrective work order and re-inspect

Follow-up

Linked work order: WO023