

Maintenance Log MLOG003

SYNTHETIC TRAINING DATA - NOT FOR OPERATIONAL OR LEGAL USE

Plant	Sahyadri Process Chemicals Plant
Period	2025-07-31 to 2025-08-13
Record Count	10
Prepared By	Maintenance Planning

Summary

Ten linked maintenance activities from the structured maintenance history. Refer to each work order for isolation and completion evidence.

Maintenance Entries

ID	Date	Equipment	Issue	Action	Technician	WO
MNT0021	2025-07-31	V214	Actuator sluggish	Service actuator	Ananya Kulkarni	WO011
MNT0022	2025-08-01	V214	Packing leak	Renew gland packing	Girish Khan	WO011
MNT0023	2025-08-03	M310	Bearing noise	Replace bearings	Meera Joshi	WO012
MNT0024	2025-08-04	M310	Overcurrent trip	Check load and cable termination	Ravi Iyer	WO012
MNT0025	2025-08-06	B503	Flame instability	Tune burner	Tanvi Gupta	WO013
MNT0026	2025-08-07	B503	Feedwater fluctuation	Service control valve	Ananya Desai	WO013
MNT0027	2025-08-09	T610	Routine condition check	Inspect, clean and function test	Girish Bhat	WO014
MNT0028	2025-08-10	T610	Routine condition check	Inspect, clean and function test	Meera Verma	WO014
MNT0029	2025-08-12	P101	Seal leakage	Replace mechanical seal	Ravi Singh	WO015
MNT0030	2025-08-13	P101	Low discharge pressure	Clean strainer and verify impeller	Tanvi Shetty	WO015