

Multi-Document Correlation Summary

Document Type: Aggregate Report *Equipment Category:* Variable Frequency Drives (VFD) *Date of Record:* 2026-03-10

1. Fleet-Wide Analysis This document correlates incident logs from 20 separate VFD units to analyze maintenance patterns. The goal is to determine the cost-effectiveness of servicing multiple similar units together versus separately.

2. Correlation Findings

- Incident correlation shows that when VFD-1 and VFD-2 (Equipment A and B) share a power bus, power surges often cause them to fail in the same week.
- Comparing failure modes across similar equipment models reveals that units located in high-dust environments (Zone 4) experience a 30% faster degradation of cooling heat sinks.