



KHYBER PAKHTUNKHWA CITIES IMPROVEMENT PROJECT
PROJECT MANAGEMENT AND CONSTRUCTION SUPERVISION CONSULTANTS
MINCONSULT SDN BHD
JOINT VENTURE
CREATIVE ENGINEERING CONSULTANTS



Ref: KPCIP/PMCSC/RE-ATD/CW-02/Lot-2/038

Date: 12th October 2023

To,

The Project Manager
ZKB-M/S T.T. SH-INSAAAT LIMITED LIABILITY COMPANY (JV)
Abbottabad

Project: ADB LOAN 4160-PAK & LOAN 8412-PAK (AIIB CO-FINANCING): KHYBER PAKHTUNKHWA CITIES IMPROVEMENT PROJECT (KPCIP); OCB-KPCIPCW-02 Procurement of Works for improvements/Construction of Water Supply System: LOT-2; Rehabilitation and upgradation of Water Supply to WTP with SCADA in Abbottabad Including New Water Treatment Plant, Abbottabad.

Subject: Submission of Test Results/Reports for Construction Materials.

Reference: 1. Your Letter No. ZKB-T. T Sh. INSAAT(JV).KPCIP/LOT-2.Abbottabad/LGE&RDD/2023/60
Dated: 5th October 2023

With reference to your above letter, we wish to confirm that the sample of water for use of concrete is fulfilling the specified limits and as such is approved for use in concrete works.

Regarding Fauji & Dewan Cement the test shows that they are failing in 3 days & 7 days compressive strength and as such rejected. Furthermore, both the submitted results for Fauji & Dewan Cements are identical which needs clarification.

Your Sincerely

Engr. Said Afsar
The Engineer/Resident Engineer
Water Supply System (Abbottabad)
PMCSC-KPCIP

Cc:

1. Project director (PMU-KPCIP, LGE&RDD).
2. Director Technical, (PMU-KPCIP, LGE&RDD).
3. Team Leader (PMCSC-KPCIP).
4. Chief Executive Officer, (WSSCA).
5. Focal Person (CIU-Abbottabad)
6. Material Engineer (PMCSC-Abbottabad)
7. Office Copy