



**GOVERNMENT OF KHYBER PAKHTUNKHWA
CITY IMPLEMENTATION UNIT (CIU-ABBOTTABAD)**



**KHYBER PAKHTUNKHWA CITIES IMPROVEMENT PROJECT
LOCAL GOVERNMENT ELECTIONS & RURAL
DEVELOPMENT DEPARTMENT**

82/3, Opposite AMC Mess, Hill Road, Abbottabad

ciuatd@gmail.com

Ref: KPCIP/CIU-ATD/CE/ 059

Date: 29/02/2024

To,

The Engineer/Resident Engineer (Water Supply),
PMCSC – KPCIP - Abbottabad

Project: Construction of WATER TREATMENT PLANT (CW2 – Lot 2 – KPCIP Abbottabad)

Subject: Observations Reported by CIU Engineer – 28-02-2024

During the field visit of KPCIP WTP site on 28-02-2024, the following irregularities are reported by the CIU Engineer:

1. After so many verbal instructions from CIU Engineers regarding Steel Rebars dumped openly without any cover on WTP construction site, the JV contractor took no action on it. Rusted Steel Rebars are stocked openly and being used in RCC in Foundation / Footings of the portion of Admin building. (Photograph Attached).
2. The rejected bricks are still on site after so many verbal and written instructions from CIU staff to remove them from the site.

PMCSC is advised to exclusively highlight this inaccuracy to the JV Contractor, instructing JV contractor for technically appropriate Warehousing of the Steel Rebars on Water Treatment Plant (WTP) construction site as well scrubbing of the Rusted Steel Bars BEFORE fixing and removal of rejected bricks from site.

Chief Engineer

City Implementation Unit (CIU)
Abbottabad

Enclosed, Photographs

Copy forwarded to

1. Project Director, PMU-KPCIP, LGE&RDD, Govt of KP.
2. Chief Executive Officer, WSSCA
3. Director Technical (PMU-KPCIP)
4. Deputy Team Leader, PMCSC Peshawar.
5. Infrastructure Engineer WATSAN, CIU Abbottabad
6. Office copy

Chief Engineer

City Implementation Unit (CIU)
Abbottabad



GOVERNMENT OF KHYBER PAKHTUNKHWA
CITY IMPLEMENTATION UNIT (CIU-ABBOTTABAD)



KHYBER PAKHTUNKHWA CITIES IMPROVEMENT PROJECT
LOCAL GOVERNMENT ELECTIONS & RURAL
DEVELOPMENT DEPARTMENT

82/3, Opposite AMC Mess, Hill Road, Abbottabad

ciuatd@gmail.com

Ref: KPCIP/CIU-ATD/CE/059

Date: 29/02/2024



Rusted Steel Rebars stocked on Water Treatment Plant (WTP) construction site



Rusted Steel Rebars on Footings of the Remaining portion of Admin building.

Handwritten signature



GOVERNMENT OF KHYBER PAKHTUNKHWA
CITY IMPLEMENTATION UNIT (CIU-ABBOTTABAD)



KHYBER PAKHTUNKHWA CITIES IMPROVEMENT PROJECT
LOCAL GOVERNMENT ELECTIONS & RURAL
DEVELOPMENT DEPARTMENT

82/3, Opposite AMC Mess, Hill Road, Abbottabad

ciuatd@gmail.com

Ref: KPCIP/CIU-ATD/CE/059

Date: 29/02/2024



Sub-standard bricks dumped on Water Treatment Plant (WTP) construction site

✓ 8