



KHYBER PAKHTUNKHWA CITIES IMPROVEMENT PROJECT
PROJECT MANAGEMENT AND CONSTRUCTION SUPERVISION CONSULTANTS
MINCONSULT SDN BHD
JOINT VENTURE
CREATIVE ENGINEERING CONSULTANTS



Ref: KPCIP/PMCSC/RE-ATD/CW-02/Lot-2/083

Date: 20th November 2023

To,

The Project Manager
ZKB-M/S T.T. SH-INSAAAT LIMITED LIBALITY COMPANY (JV)
Abbottabad

149

Project: ADB LOAN 4160-PAK & LOAN 8412-PAK (AIIB CO-FINANCING): KHYBER PAKHTUNKHWA CITIES IMPROVEMENT PROJECT (KPCIP); OCB-KPCIPCW-02 Procurement of Works for improvements/Construction of Water Supply System: LOT-2: Rehabilitation and upgradation of Water Supply to WTP with SCADA in Abbottabad Including New Water Treatment Plant, Abbottabad.

Subject: Non-Compliance SSHSMP Under Sub Clause 6.7 of GCC/PCC.

Traffic Management Plan REF 08:

The JV Contractor didn't Install the sign board at the service Road, Fire Points, no safety cone/ divider tolls, entrance and exit of the HTV and Proper plan as per site attached to the traffic management plan.

Accident/Incident REF 6.4:

JV Contractor submitted the letter with reference ZKB-T. T Sh. INSAAT(JV). KPCIP/LOT-2. Abbottabad/ LGE&RDD/2023/91 dated about excavation to follow the SSHSMP during the excavation but noncompliance observed and incident/Accident happen at 15:30hrs dated 16th Nov 2023 during the excavation of the structure number 13 & 14. During the Activity the unstable, excavated material slipped and fell to the service road. During the removal of fallen material the boom of excavator damages the 4x Concrete Slab panel and 1x column of the boundary wall parallel to the service road.

Site Specific Health & Safety Standard REF 7.7:

To proceed the Ongoing Activity at excavated area the safe access is the priority to follow the SSHSMP Ref 7.7 For the safety of all workers and operation. Noncompliance observed during the laying of steel at the distribution Chamber.

Site Specific Health & Safety Standard REF 7.2:

The JV Contractor did not provide the PPE (Safety Shoes) to the employee. PPE REF 7.2.

As per clause 6.7 of the contract agreement SSHSMP, if the noncompliance is observed after the date of commencement penalty is 3000 Pkr/day.

Your Sincerely,

Engr. Said Afsar
The Engineer/Resident Engineer
Water Supply System (Abbottabad)
PMCSC-KPCIP

Follow-up for complete

30/11/2023