



**GOVERNMENT OF KHYBER PAKHTUNKHWA
CITY IMPLEMENTATION UNIT (CIU-ABBOTTABAD)**



**KHYBER PAKHTUNKHWA CITIES IMPROVEMENT PROJECT
LOCAL GOVERNMENT ELECTIONS & RURAL
DEVELOPMENT DEPARTMENT**

82/3, Opposite AMC Mess, Hill Road, Abbottabad
ciuabtd@gmail.com

Ref: KPCIP/CIU-AID/CE/230

Date: 15/01/2024

To,

The Engineer/Resident Engineer (Water Supply)
PMCSC – KPCIP - Abbottabad

Project: CW2 – Lot 2 – KPCIP Abbottabad

Subject: Observations – Faults & Lapses on Site

During the field visit of KPCIP WTP site on 10-01-2024, the following flaws / errors are reported by the CIU Water Supply Team: -

1. The CIU team reached on site at 2:40 pm, however no responsible person from PMCSC was present.
2. Rusted steel bars were fixed for plinth beams at sub-station building.
3. Despite the clear instructions on 08-01-2021 by CIU engineers for removal, sub-standard bricks were still dumped on site.

PMCSC is advised to ensure the presence of site inspectors on site during contractor's activities, supervise the work standards and closely monitor the site-specific practices as described in the contract.


Enclosed: Pictures


Chief Engineer

City Implementation Unit (CIU)
Abbottabad

Copy forwarded to

1. Project Director, PMU-KPCIP, LGE&RDD, Govt of KP.
2. Chief Executive Officer, WSSCA
3. Director Technical (PMU-KPCIP)
4. Deputy Team Leader, PMCSC Peshawar.
5. Infrastructure Engineer WATSAN, CIU Abbottabad
6. Office copy


Chief Engineer

City Implementation Unit (CIU)
Abbottabad