



**KHYBER PAKHTUNKHWA CITIES IMPROVEMENT PROJECT**  
PROJECT MANAGEMENT AND CONSTRUCTION SUPERVISION CONSULTANTS  
**MINCONSULT SDN BHD**  
JOINT VENTURE  
**CREATIVE ENGINEERING CONSULTANTS**



KPCIP/PMSCS/RE-ATD/CW-02/Lot-1/029

Date: 10<sup>th</sup> January 2024

To,

**The Deputy Project Manager**

ZKB-M/S T.T. SH-INSAAAT LIMITED LIABILITY COMPANY (JV)  
Abbottabad

**Project:** KHYBER PAKHTUNKHWA CITIES IMPROVEMENT PROJECT (KPCIP); OCB-KPCIP-CW-2: PROCUREMENT OF WORKS FOR IMPROVEMENT / CONSTRUCTION OF WATER SUPPLY SYSTEM: Lot-1: Rehabilitation and Upgradation of Water Supply Connected to the WTP with SCADA in Abbottabad including: A. Rehabilitation or Provision of Water Storage Reservoirs; B. New Distribution Network; C. Intake Structure Including Transmission Main and Associated Structures

**Subject:** Submission of 4x Financial Quotations for Standard Penetration Test (SPT) at Project Site.

**Reference:** 1. Your Letter No. ZKB-T. T Sh. INSAAT(JV). KPCIP/LOT-1/ATD/LGE&RDD/24/016  
Dated: 8<sup>th</sup> January 2024

With reference to your above letter, we wish to inform you that out of 4 submitted quotations the quotation no.1 of vendor GSK Engineers being the lowest is acceptable with the condition that 5 nos. SPT are to be conducted in a depth of 10 m & 2 m interval as mention in the attached specification because the vendor has not mentioned the number of SPT in the quotations.

Your Sincerely,

**Engr. Said Afsar**

The Engineer/Resident Engineer  
Water Supply System (Abbottabad)  
PMSCS-KPCIP

Cc:

1. Project Director, (PMU-KPCIP, LGE&RDD).
2. Director Technical, (PMU-KPCIP, LGE&RDD).
3. Contract Expert (PMSCS-KPCIP)
4. Chief Executive Officer, (WSSCA)
5. Contract & Claim Engineer (PMSCS-KPCIP)
6. Focal Person (CIU-Abbottabad)
7. Office Copy