



**GOVERNMENT OF KHYBER PAKHTUNKHWA**  
**CITY IMPLEMENTATION UNIT (CIU-ABBOTTABAD)**



**KHYBER PAKHTUNKHWA CITIES IMPROVEMENT PROJECT**  
**LOCAL GOVERNMENT ELECTIONS & RURAL**  
**DEVELOPMENT DEPARTMENT**

82/3, Opposite AMC Mess, Hill Road, Abbottabad  
[ciuatd@gmail.com](mailto:ciuatd@gmail.com)

Ref: KPCIP/CIU-ATD/CE/079

Date: 22/03/2024

To,

The Engineer/Resident Engineer (Water Supply)  
PMCSC – KPCIP - Abbottabad

**PROJECT: Construction of WATER TREATMENT PLANT (CW2- Lot 2 - KPCIP Abbottabad)**

**SUBJECT: Observations Reported by CIU Engineer 20-03-2024**

During the field visit of KPCIP WTP site on 20-03-2024, the following flaws / errors are reported by the CIU Water Supply Team: -

1. Use of unsuitable and unspecified material for backfilling over 560 mm Dia HDPE pipe.
2. Unspecified methodology used for compaction of backfill behind plum concrete wall where on a layer more than 2 meter is being compacted which is contrary to the specification.
3. Rejected bricks are present on site.
4. Inadequate curing of structures is noted. PMCSC shall instruct JV contractor for submission of curing schedule.
5. Rebar is lying in open air without proper warehousing making rebars rusted. The same observation is communicated to PMCSC vide on previous letter no KPCIP/CIU-ATD/CE/059 on dated 29/02/2024.

PMCSC is advised to ensure the quality assurance on site, supervise the work standards and closely monitor the site-specific practices as described in the contract.

Enclosed: Pictures

Copy forwarded to

1. Project Director, PMU-KPCIP, LGE&RDD, Govt of KP.
2. Chief Executive Officer, WSSCA
3. Director Technical (PMU-KPCIP)
4. Deputy Team Leader, PMCSC Peshawar.
5. Infrastructure Engineer WATSAN, CIU Abbottabad
6. Office copy

Chief Engineer / Focal Person  
City Implementation Unit (CIU)  
Abbottabad

Chief Engineer / Focal Person  
City Implementation Unit (CIU)





**GOVERNMENT OF KHYBER PAKHTUNKHWA**  
**CITY IMPLEMENTATION UNIT (CIU-ABBOTTABAD)**



**KHYBER PAKHTUNKHWA CITIES IMPROVEMENT PROJECT**  
**LOCAL GOVERNMENT ELECTIONS & RURAL**  
**DEVELOPMENT DEPARTMENT**  
82/3, Opposite AMC Mess, Hill Road, Abbottabad  
[ciuatd@gmail.com](mailto:ciuatd@gmail.com)

Ref: KPCIP/CIU-ATD/CE/1228

Date: 03/2024  
Abbottabad



Filling of 560 HDPE pipe with unsuitable material according to the specification. ✓



Back filling of left side plum concrete retaining wall not according to the specification





**GOVERNMENT OF KHYBER PAKHTUNKHWA**  
**CITY IMPLEMENTATION UNIT (CIU-ABBOTTABAD)**



**KHYBER PAKHTUNKHWA CITIES IMPROVEMENT PROJECT**  
**LOCAL GOVERNMENT ELECTIONS & RURAL**  
**DEVELOPMENT DEPARTMENT**

82/3, Opposite AMC Mess, Hill Road, Abbottabad  
[ciuatd@gmail.com](mailto:ciuatd@gmail.com)

Ref: KPCIP/CIU-ATD/CE/078

Date: /03/2024



Rejected bricks present on site



Rebar is lying in open air without proper warehousing making rebars rusted.