



## WATER AND SANITATION SERVICES COMPANY ABBOTTABAD

(Registered Under Section 42 of the Companies Ordinance 1984)  
Ph: 0992-9311048, Email: [wsscabbottabad@gmail.com](mailto:wsscabbottabad@gmail.com)



No. CEO/WSSCA/023/9395

31/10/2023

To,

The Engineer/Resident Engineer (Water Supply)  
PMSCS – KPCIP, Abbottabad


**Project: KHYBER PUKHTUNKHAWA CITY IMPROVEMENT PROJECT (KPCIP) - ABBOTTABAD**

**Subject: CW2 – Lot 1 – Missing Specifications of MS PIPE**

Reference to the BOQ, KPCIP-CW-2: Procurement of Works for Improvement / Construction of Water Supply System, Abbottabad, Bill No. 2 (Pipes & Fittings and Marker Tape), Article 2.1 (Providing & Fixing of MS Pipe)


It is important to apprise that a basic specification i.e. THICKNESS / GAUGE OF THE MS PIPE is not given in the item description. This information is not included in the design report as well. Similarly, the relevant details of the pipeline work, i.e., Weight of Pipe and welding standards are also not provided in the BOQ which are fundamental references for setting the benchmarks during field inspections.

PMSCS is advised to address this deficiency and share the missing details as mentioned above before commencement of work.

  
Chief Executive Officer  
Water and Sanitation Services Company,  
Abbottabad

Copy Forwarded to;

1. The Project Director, PMU – KPCIP, Peshawar
2. The Director (Technical), PMU-KPCIP
3. The Focal Person – CIU – KPCIP Abbottabad
4. The Infrastructure Engineer (WATSAN), CIU – KPCIP, Abbottabad
5. The Team Leader – PMSCS - KPCIP
6. Office file.

  
Chief Executive Officer  
Water and Sanitation Services Company,  
Abbottabad