



KHYBER PAKHTUNKHWA CITIES IMPROVEMENT PROJECT
PROJECT MANAGEMENT AND CONSTRUCTION SUPERVISION CONSULTANTS
MINCONSULT SDN BHD
JOINT VENTURE
CREATIVE ENGINEERING CONSULTANTS



Ref: KPCIP/PMCSC/RE-ATD/CW-02/Lot-2/063

Date: 2nd November 2023

To,

The Project Manager
ZKB-M/S T.T. SH-INSAAAT LIMITED LIBALITY COMPANY (JV)
Abbottabad

Project: ADB LOAN 4160-PAK & LOAN 8412-PAK (AIIB CO-FINANCING): KHYBER PAKHTUNKHWA CITIES IMPROVEMENT PROJECT (KPCIP); OCB-KPCIPCW-02 Procurement of Works for improvements/Construction of Water Supply System: LOT-2; Rehabilitation and upgradation of Water Supply to WTP with SCADA in Abbottabad Including New Water Treatment Plant, Abbottabad.

Subject: Submission of Shop Drawings for "Distribution Chamber" & "Guard Room".


Reference: 1. Your Letter No. ZKB-T. T Sh. INSAAT(JV).KPCIP/LOT-2.Abbottabad/LGE&RDD/ 2023/40 Dated: 22nd September 2023
2. Your Letter No. ZKB-T. T Sh. INSAAT(JV).KPCIP/LOT-2.Abbottabad/LGE&RDD/ 2023/23 Dated: 15th September 2023

With reference to your above letters, we wish to inform you that guard room location is under shifting & will be dealt separately. However, your submitted shop drawing is approved except that:

1. RCC 1:1:2 be replaced by 4000 Psi as mentioned in note no.7 of general note (Structural).
2. Overlap be provided at 3.50 m from the bottom.
3. The NSL 1371.10 m shown on shop drawing be replaced by 1370.97.

In view of above you can continue your construction with the above correction & resubmit your shop drawing for our approval.

Your Sincerely,


Engr. Said Afsar
The Engineer/Resident Engineer
Water Supply System (Abbottabad)
PMCSC-KPCIP

Cc:

1. Project Director (PMU-KPCIP, LGE&RDD).
2. Director Technical (PMU-KPCIP, LGE&RDD).
3. Team Leader (PMCSC-KPCIP)
4. Chief Quantity Surveyor (PMCSC-KPCIP)
5. Chief Executive Officer, (WSSCA)
6. **Focal Person (CIU-Abbottabad)**
7. Office File