



**WATER AND SANITATION SERVICES COMPANY  
ABBOTTABAD**

(Registered Under Section 42 of the Companies Ordinance 1984)  
Ph: 0992-9311048, Email: [wsscabbottabad@gmail.com](mailto:wsscabbottabad@gmail.com)



No. CEO/WSSCA/023/ 9316

18/10/2023

To,


The Engineer/Resident Engineer (Water Supply)  
Project Management and Construction Supervision Consultant,  
Khyber Pakhtunkhwa Cities Improvement Project,  
Abbottabad

Project: KHYBER PUKHTUNKHAWA CITY IMPROVEMENT PROJECT (KPCIP)  
CW-02 Lot 2 (Water Treatment Plant - Abbottabad)

Subject: Using of PHED Premises as Entry Way for Distribution Chamber (Raw Water Inlet)

Reference to the IFC Drawing CEC-WTP-ABT-1510 (Piping Layout Plan) wherein the Raw Water Pipe is approaching the Distribution Chamber from inside of the PHED WTP whereas this approach should be arranged within the KPCIP WTP facility.


In this context, PMCSC is advised to re-align the Raw Water / Distribution Chamber Inlet Pipe in accordance with the KPCIP WTP premises to avoid any after-effects in future.

  
Chief Executive Officer  
Water and Sanitation Services Company,  
Abbottabad

Copy Forwarded to;

1. The Project Director, PMU – KPCIP, Peshawar
2. The Director (Technical), PMU-KPCIP
3. The Team Leader, PMCSC, Peshawar
4. The Focal Person -- CIU – KPCIP Abbottabad
5. The Infrastructure Engineer (WATSAN), CIU – KPCIP, Abbottabad
6. Office file.

*Received  
20/10/23  
Amir  
Riaz*

  
Chief Executive Officer  
Water and Sanitation Services Company,  
Abbottabad

*20/10/23*