



**GOVERNMENT OF KHYBER PAKHTUNKHWA
CITY IMPLEMENTATION UNIT (CIU-ABBOTTABAD)**



**KHYBER PAKHTUNKHWA CITIES IMPROVEMENT PROJECT
LOCAL GOVERNMENT ELECTIONS & RURAL
DEVELOPMENT DEPARTMENT**

82/3, Opposite AMC Mess, Hill Road, Abbottabad

ciuatd@gmail.com

Ref: KPCIP/CIU-ATD/CE/15

Date: 13 / Dec / 2023

To,

The Engineer/Resident Engineer (Water Supply)
PMCSC – KPCIP - Abbottabad

Project: CW2 – Lot 2 – KPCIP Water Treatment Plant, Abbottabad

Subject: Reminder – Urgent Resolution Required for Rusted Steel Rebars and Quality Control at WTP Construction Site

This is in continuation of our Letter Reference No. KPCIP/CIU-ATD/CE/11 dated 07-12-2023.

It is shared with great concern that PMCSC has not paid any attention to the concerns shared by CIU in the above referred letter. During the field visit of CIU Engineers on 13-12-2023, a significant quantity of the rusted steel bars was found in the stock yard due to inappropriate / exposed warehousing.


PMCSC is once again advised to exclusively highlight this inadequacy to the JV Contractor, directing him for technically appropriate warehousing of the steel rebars as well scrubbing of the rusted steel bars BEFORE fixing. Furthermore, steel fixing or concreting should be aggregately disallowed if the sub-standard materials or poor workmanship is attempted by the JV Contractor for any piece of work.


Chief Engineer / Focal Person
City Implementation Unit (CIU),
Abbottabad

Enclosed for Reference: Picture 1, 2 & 3

Copy Forwarded to:

1. The Chief Executive Officer, WSSC Abbottabad
2. The Infrastructure Engineer (WATSAN) CIU – Abbottabad
3. The Team Leader, KPCIP-PMCSC, Peshawar
4. Office Copy


Chief Engineer / Focal Person
City Implementation Unit (CIU),
Abbottabad

