

WATER AND SANITATION SERVICES COMPANY ABBOTTABAD



(Registered Under Section 42 of the Companies Ordinance 1984)
Ph: 0992-9311048, Email: wsscabbottabad@gmail.com

No. CEO/WSSCA/022/<u>82</u>00



Date: \$\frac{1}{2}/02/2023

To;

The Engineer/Resident Engineer
Project Management and Construction Supervision Consultant,

Khyber Pakhtunkhwa Cities Improvement Project,

Abbottabad

Subject:

KHYBER PUKHTUNKHAWA CITY IMPROVEMENT PROGRAM (KP-CIP PROJECT)

DEVLOPMENT OF URBAN/GREEN SPACES AND PARKS; LOT-1: PEDESTRIANISATION OF OLD CITY BAZAR & DEVELOPMENT OF SHERWAN HILL PARK.

This is in light of CIU's team of sub engineer's visit to the project's site (Sherwan Hill Family Adventure Park's) on Sunday 12th February 2023 and a subsequent visit of Contracts Manager and Focal Person to CEO on Thursday 16th February 2023 as well as CIU's sub engineer's visit on Monday 20th February 2023. During the visit following observations are made and are hereby submitted for your information and necessary action on priority:

Sr.	Observation	Remarks
No.		Remarks
i.	R.C.C Raft of Restaurant Building was done at site, Two Slum cone tests were carried out, both of which failed as the slump was exceeding the specified range. Furthermore, despite the instructions of CIU's team they did not rectify nor controlled the w/c ratio and the pouring was done with the loose slump.	This substandard work was done despite the presence PMSCS's supervision team. Necessary instructions must be given to site supervision team to ensure the quality of work.
ii.	The Footing's Reinforcement of a Cafeteria was measured during a visit on 16th February 2023 by the CIU Team on and it was found way less the designed measurements. The site inspector of PMCSC was called on site to explain to which he said the construction drawings were changed by the RE and he was holding an unsigned copy of it. Still, the laid reinforcement was not meeting the required measurements having differences of 6 inches to 18 inches. In the end it was agreed by everyone present, that the Reinforcement will be laid again as per designed specifications and an RFI will be	It was revealed during Yesterday's visit (i.e. 20th February) that Pouring was done without prior notice to the CIU's team despite being asked to do so. The undersigned will not approve the payment for the aforementioned works unless the reinforcement is laid again and inspected by the CIU's team. Moreover, In future a copy of RFI must



WATER AND SANITATION SERVICES COMPANY ABBOTTABAD



(Registered Under Section 42 of the Companies Ordinance 1984)
Ph: 0992-9311048, Email: wsscabbottabad@gmail.com

	Ph: 0992-9311048, Email: wsscap	t it the CIII toom
	shared with the CIU's team well befor	be shared with the Clo team
	concrete pouring.	timely.
iii.	There is no proper curing method being adopted at site, as per desired/required standards since the commencement of works at site.	followed under the supervision of your team at
iv	The alignment and verticality of Retaining wall along cricket ground (0+000 to 0+005) is out of shape and needs to be fixed.	pictorial evidence attached below. Dismantling is recommended.
	The practice of hand mixing for such a mega project not only against the acceptable standards but also a matter of grave concern for the employer. Also, the approved mix design was not available on site and the mortar mix was being carried out on hit and trial.	this practice and proper equipment (i.e. mixer) must

The pictorial evidence of above observations and DPRs is attached for your reference, record and necessary action at your end on top priority. This state of affairs and poor quality of work is an embarrassment for all concerned. It is therefore desired to get it rectified and ensure proper supervision at site, please.

Chief Executive Officer
Water and Sanitation Services Company,
Abbottabad

Copy Forwarded to;

- 1. Director (Technical) PMU, KPCIP Peshawar.
- 2. Contracts Manager, CIU-Abbottabad.
- 3. Focal Person, CIU-Abbottabad, KPCIP.
- 4. Team Leader/CRE PMCSC, Peshawar.