

Ref: KPCIP/PMSCS/RE-ATD/CW-02/Lot-2/155

Date: 9<sup>th</sup> March 2024

To,

Chief Engineer  
City Implementation Unit  
Abbottabad

307

**Project:** ADB LOAN 4160-PAK & LOAN 8412-PAK (AIIB CO-FINANCING): KHYBER PAKHTUNKHWA CITIES IMPROVEMENT PROJECT (KPCIP); OCB-KPCIPCW-02 Procurement of Works for improvements/Construction of Water Supply System: LOT-2; Rehabilitation and upgradation of Water Supply to WTP with SCADA in Abbottabad Including New Water Treatment Plant, Abbottabad.

**Subject:** Observations Reported by CIU Engineer (28-02-2024).

**Reference:** 1. Your Letter No. KPCIP/CIU-ATD/CE/059

Dated: 29<sup>th</sup> February 2024

With reference to your above letter our response is as under:

1. Contractor has been instructed to protect the dumped steel rebars by properly covering up however the rust is clean prior to covering it up with concrete.
2. The rejected bricks have already been removed from the site since 6<sup>th</sup> March 2024.

Hope the above explanation clarify the situation.

Your Sincerely,



**Engr. Said Afsar**  
The Engineer/Resident Engineer  
Water Supply System (Abbottabad)  
PMSCS-KPCIP

Cc:

1. Project director (PMU-KPCIP, LGE&RDD).
2. Director Technical, (PMU-KPCIP, LGE&RDD).
3. Min-Consult Representative
4. Contract Expert, (PMSCS-KPCIP).
5. Contract & Claim Engineer, (PMSCS-KPCIP)
6. Chief Executive Officer, (WSSCA).
7. Office Copy