

KPCIP/PMSCS/RE-ATD/CW-02/Lot-1/045

Date: 30<sup>th</sup> January 2024

To,

The Deputy Project Manager,  
ZKB-M/S T.T. SH-INSAAAT LIMITED LIABILITY COMPANY (JV)  
Abbottabad

Project:

**KHYBER PAKHTUNKHWA CITIES IMPROVEMENT PROJECT (KPCIP); OCB-KPCIP-CW-2: PROCUREMENT OF WORKS FOR IMPROVEMENT / CONSTRUCTION OF WATER SUPPLY SYSTEM: Lot-1: Rehabilitation and Upgradation of Water Supply Connected to the WTP with SCADA in Abbottabad including: A. Rehabilitation or Provision of Water Storage Reservoirs; B. New Distribution Network; C. Intake Structure Including Transmission Main and Associated Structures**

Subject:

**Submission of Method Statement for Laying of MS Pipeline.**

Reference: 1. Your Letter No: ZKB-T. T Sh: INSAAT(JV).KPCIP/LOT-1.Abbottabad/LGE&RDD/2024/019 Dated: 18<sup>th</sup> January 2024

With reference to your above letter, we wish to inform you that the MS plate of 7mm thickness which was jointly collected with your representative from "Mehboob Steel Pipe Industries" and submitted to 'University of Engineering & Technology, Lahore' for physical & chemical testing. The attached test results are fulfilling the specification requirements and as such your submitted method statement is acceptable for your onwards working.

However, once the MS plate is delivered on site, sample will be taken for third party testing. Please note that the welded joints shall conform to water distribution networks specification chapter 4.1.6.10.3.

Your Sincerely,

  
Engr. Said Afsar


The Engineer/Resident Engineer  
Water Supply System (Abbottabad)  
PMSCS-KPCIP

Cc:

1. Project director (PMU-KPCIP; LGE&RDD).
2. Director Technical, (PMU-KPCIP, LGE&RDD)
3. Contract & Claim Engineer (PMSCS-KPCIP)
4. Chief Executive Officer, (WSSCA).
5. Focal Person (CIU-Abbottabad)
6. Material Engineer(WTP-Abbottabad)
7. Office Copy

WLS  
2

Review  
disun



Urgent

Chief Engr.

Why our comments not attended.

Received By  
Adalat Mansoor

30/01/24