

Ref: KPCIP/PMCSC/RE-ATD/CW-02/Lot-2/045

Date 23rd October 2023

To

The Project Manager

ZKB-M/S T T SH-INSAAAT LIMITED LIBALITY COMPANY (JV)
Abbottabad

Project: ADB LOAN 4160-PAK & LOAN 8412-PAK (AIIB CO-FINANCING): KHYBER PAKHTUNKHWA CITIES IMPROVEMENT PROJECT (KPCIP); OCB-KPCIPCW-02 Procurement of Works for improvements/Construction of Water Supply System: LOT-2; Rehabilitation and upgradation of Water Supply to WTP with SCADA in Abbottabad Including New Water Treatment Plant, Abbottabad.

Subject: Discrepancy of Steel DIA's in Construction Drawings & their Market Availability.

Reference: 1. Your Letter No. ZKB-T. T Sh. INSAAT(JV) KPCIP/LOT-2 Abbottabad/LGE&RDD/ 2023/63 Dated 6th October 2023

In reference to your above letter, we wish to confirm that our design section has approved the use of steel bar 12mm instead of 13mm & 20mm instead of 19mm.

Hope this resolve the issue.

Your Sincerely



Engr. Said Afsar

The Engineer/Resident Engineer
Water Supply System (Abbottabad)
PMCSC-KPCIP

Cc:

1. Project Director (PMU-KPCIP, LGE&RDD)
2. Director *Technical* (PMU-KPCIP, LGE&RDD)
3. Team Leader (PMCSC-KPCIP)
4. Project Design and Supervision Coordinator (DTL), (PMCSC-KPCIP)
5. Contract Expert (PMCSC-KPCIP)
6. Contract & Claim Engineer (PMCSC-KPCIP)
7. Structure Design Engineer (PMCSC-KPCIP)
8. Chief Executive Officer, (WSSCA)
9. Focal Person (CIU-Abbottabad)
10. Office Copy