



# OFFICE OF THE CHIEF EXECUTIVE OFFICER

WATER AND SANITATION SERVICES COMPANY ABBOTTABAD

(Registered Under Section 42 of the Companies Ordinance 1984)



No. CEO/WSSCA/2022-23/ 8330

Date. 28/03/2023

To,

The Engineer / Resident Engineer  
JV – Creative Engineering Consultant and Minconsult  
Project Management & Construction Supervision Consultant  
Green Urban Spaces Development Projects Abbottabad  
Khyber Pakhtunkhwa Cities Improvement Project (KPCIP)  
Abbottabad

**Project:** KHYBER PAKHTUNKHWA CITIES IMPROVEMENT PROJECT  
OCB/KPCIP/CW-01: DEVELOPMENT OF URBAN / GREEN SPACES AND PARKS  
LOT-1: PEDESTRIANIZATION IN OLD CITY CENTRE: URBAN / GREEN SPACES INITIATIVES – SHERWAN  
FAMILY ADVENTURE PARK, ABBOTTABAD

**Subject:** DESIGN FACILITIES IN FRONT OF SARAFA BAZAR

**Sub:** WSSCA's RESPONSE


- Ref:**
1. KPCIP/PMCSC/RE/ATD/LOT-1/041 dated 13-03-2023
  2. CEO/WSSCA/023/8161 dated 15-02-2023
  3. Minutes of Meeting of 3<sup>rd</sup> GRC Meeting issued vide Letter of Transmittal bearing No. CEO/WSSCA/2023/8122 dated 07-02-2023; copied to RE – Pedestrianization Project, PMCSC, KPCIP for Necessary Actions
  4. Email from the undersigned dated Feb 10, 2023 under subject *Re: Urgent: Work halted at site of ladies washrooms and prayer area*
  5. Email from Director Compliance dated Feb 10, 2023 addressed to DTL – PMCSC under subject *Re: Urgent: Work halted at site of ladies washrooms and prayer area*

Please refer to the above listed communications in context with the subject matter.

The design requirements as induced from the recommendations of the GRC are briefed here below.


- i. Washrooms shall be proposed at road level and the open plot be excavated on the side whereon the defunct water filtration plant is located. As calculated from the drawings shared by TMA, the plot may be excavated to a length of around 20 feet or as required per site considering the minimum requirements for construction of washrooms (Ladies etc.)
- ii. The top of the washrooms and the remaining plot be kept open and green.
- iii. To ensure controlled access to plot, the sides of the plot be provided with elevated flower beds being planted with climbers so that the plot be kept enclosed with an aesthetic outlook. This recommendation is added by the City Level Project Administration & Management Committee (CLPAMC) during visit dated March 09, 2023.
- iv. Other design requirement/amenities be adjusted accordingly considering the basis mentioned above.

The revised design may be shared at the earliest, please.

  
Chief Executive Officer  
Water & Sanitation Services Company Abbottabad  
Abbottabad

CC:

1. The Project Director, PMU – KPCIP
2. The Director Technical, PMU – KPCIP
3. The Director Compliance, PMU – KPCIP
4. The Team Leader, PMCSC – KPCIP
5. The Focal Person, CIU Abbottabad, KPCIP
6. The Project Manager (M/s Reliable – JHK (JV))
7. Office Copy

  
Chief Executive Officer  
Water & Sanitation Services Company Abbottabad  
Abbottabad